

OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: MAY 22

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				SYSTEM off			
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16	off	off	.01	off	off	off	.01
17	off	off	.01	off	off	off	.01
18	off	off	.01	off	off	off	.01
19				SYSTEM off			
20							
21							
22							
23	off	off	.01	off	off	off	.01
24	off	off	.01	off	off	off	.01
25	off	off	.01	off	off	off	.01
26	off	off	.01	off	off	off	.01
27				SYSTEM off			
28							
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes:	PRINTED NAME: <u>Frank Jensen</u>	DATE: <u>6-1-22</u>
	SIGNATURE: <u>[Signature]</u>	PHONE #: <u>(541) 832-2202</u>
		CERT #: <u>⊘</u>



Data Mgmt & Compliance
Drinking Water Program

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/								
2/								
3/								
4/								
5/								
6/								
7/								
8/								
9/								
10/								
11/								
12/								
13/								
14/								
15/								
16/	.35	210	73.5	14.5	7.58	32	yes	
17/	.35	210	73.5	14.7	7.61	33	yes	
18/	.35	210	73.5	13.9	7.63	36	yes	
19/			system off					
20/								
21/								
22/								
23/	.41	210	86.1	13.8	7.64	36	yes	
24/	.62	210	130.2	16.1	7.53	28	yes	
25/	.62	210	130.2	16.7	7.55	28	yes	
26/	.59	210	123.9	17.2	7.44	25	yes	
27/			System off					
28/								
29/								
30/								
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013. Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf

