

OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: July 22

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			System off				
2							
3							
4							
5							
6							
7							
8	off	off	.02	off	off	off	.02
9	off	off	.02	off	off	off	.02
10			System off				
11							
12							
13	off	off	.10	off	off	off	.10
14	off	off	.10	off	off	off	.10
15	off	off	.10	off	off	off	.10
16	off	off	.10	off	off	off	.10
17			System off				
18							
19							
20	off	off	.02	off	off	off	.02
21	off	off	.02	off	off	off	.02
22	off	off	.01	off	off	off	.01
23			System off				
24							
25							
26							
27							
28							
29	off	off	.01	off	off	off	.01
30	off	off	.02	off	off	off	.02
31	off	off	.02	off	off	off	.02

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes/ No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes/ No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes/ No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes/ No
Notes: #2 filter used 7-15 to 7-16	PRINTED NAME: Fred Jensen	
	SIGNATURE: <i>[Signature]</i>	DATE: 8-1-22
	PHONE #: (501) 832-2202	CERT #: <i>[Symbol]</i>

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			System off					
2/								
3/								
4/								
5/								
6/								
7/								
8/	.45	210	94.5	22.0	7.59	19	yes	
9/	.56	210	117.6	20.3	7.45	21	yes	
10/			System off					
11/								
12/								
13/	.37	210	77.7	22.7	7.57	19	yes	
14/	.51	210	107.1	21.4	7.58	20	yes	
15/	.51	210	107.1	20.1	7.56	22	yes	
16/	.49	210	102.9	21.2	7.56	20	yes	
17/			System off					
18/								
19/								
20/	.36	210	75.6	23.1	7.56	17	yes	
21/	.48	210	100.8	22.3	7.41	18	yes	
22/	.52	210	109.2	22.7	7.43	18	yes	
23/			System off					
24/								
25/								
26/								
27/								
28/								
29/	.40	210	84	22.4	7.52	19	yes	
30/	.48	210	100.8	24.8	7.48	15	yes	
31/	.48	210	100.8	24.8	7.44	15	yes	

³ If Cl₂ at entry point < 0.2 mg/L OR CT not met, notify DWS within 24 hours. Revised October 2013 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf

AUG 03 2022