

OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane Diatomaceous Earth Filtration or Unfiltered Systems /

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: 11-22

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			System off				
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14	off	off	.01	off	off	off	.01
15	off	off	.01	off	off	off	.01
16	off	off	.01	off	off	off	.01
17	off	off	.01	off	off	off	.01
18	off	off	.02	off	off	off	.02
19			System off				
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU ² All daily turbidity readings ≤ 5 NTU?	CT's met everyday? (see back) Yes/No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes/No
Notes:	PRINTED NAME: Fred Jensen	DATE: 12-3-22
	SIGNATURE: [Signature]	CERT #: 0
	PHONE #: 541 1832-2202	

RECEIVED
DEC 06 2022
Data Mgmt & Compliance
Drinking Water Program

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Date / Time	Minimum Cl ₂ Residual at User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			System off					
2/								
3/								
4/								
5/								
6/								
7/								
8/								
9/								
10/								
11/								
12/								
13/								
14/	.75	210	157.5	11.8	7.49	40	Yes	
15/	.75	210	157.5	11.3	7.54	41	Yes	
16/	.73	210	153.3	12.3	7.44	37	Yes	
17/	.72	210	151.2	10.8	7.42	43	Yes	
18/	.72	210	151.2	10.7	7.36	42	Yes	
19/			System off					
20/								
21/								
22/								
23/								
24/								
25/								
26/								
27/								
28/								
29/								
30/								
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013. Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb_alt-unfiltered.pdf

RECEIVED
DEC 06 2022