

**OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane
Diatomaceous Earth Filtration or Unfiltered Systems**

System Name: Fir Point Bible Conference **ID #:** OR4192108 **WTP:-**WTP-A **Month/Year:** 12-22

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			System off				
2	↓	↓	↓	↓	↓	↓	
3	↓	↓	↓	↓	↓	↓	
4	↓	↓	↓	↓	↓	↓	
5	↓	↓	↓	↓	↓	↓	
6	↓	↓	↓	↓	↓	↓	
7	↓	↓	↓	↓	↓	↓	
8	↓	↓	↓	↓	↓	↓	
9	↓	↓	↓	↓	↓	↓	
10	↓	↓	↓	↓	↓	↓	
11	↓	↓	↓	↓	↓	↓	
12	↓	↓	↓	↓	↓	↓	
13	off	off	.01	off	off	off	.01
14	off	off	.02	off	off	off	.02
15	off	off	.02	off	off	off	.02
16			System off				
17	↓	↓	↓	↓	↓	↓	
18	↓	↓	↓	↓	↓	↓	
19	↓	↓	↓	↓	↓	↓	
20	↓	↓	↓	↓	↓	↓	
21	↓	↓	↓	↓	↓	↓	
22	↓	↓	↓	↓	↓	↓	
23	↓	↓	↓	↓	↓	↓	
24	↓	↓	↓	↓	↓	↓	
25	↓	↓	↓	↓	↓	↓	
26	↓	↓	↓	↓	↓	↓	
27	↓	↓	↓	↓	↓	↓	
28	↓	↓	↓	↓	↓	↓	
29	↓	↓	↓	↓	↓	↓	
30	↓	↓	↓	↓	↓	↓	
31	↓	↓	↓	↓	↓	↓	

RECEIVED
JAN 05 2023
Certification
Drinking Water Services

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Notes: CAMP CLOSED IN DECEMBER	PRINTED NAME: Fred Jensen	
	SIGNATURE: <i>[Signature]</i>	DATE: 1-2-23
	PHONE #: (541) 832-2202	CERT #: 0

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Date / Time	Minimum Cl ₂ Residual at User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			System off					
2/								
3/								
4/								
5/								
6/								
7/								
8/								
9/								
10/								
11/								
12/								
13/	.46	210	92.6	9.2	7.67	48	yes	
14/	.55	210	115.5	13.7	7.49	34	yes	
15/	.57	210	119.7	10.4	7.40	42	yes	
16/			System off					
17/								
18/								
19/								
20/								
21/								
22/								
23/								
24/								
25/								
26/								
27/								
28/								
29/								
30/								
31/								

RECEIVED
 JAN 05 2023
 Certification
 Drinking Water Services

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf