

FEB 03 2023

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems Drinking Water Services

System Name: Fir Point Bible Conference ID #:OR4192108 WTP-:WTP-A Month/Year: 1-23

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			SYSTEM off				
2	↓	↓	↓	↓	↓	↓	
3	↓	↓	↓	↓	↓	↓	
4	↓	↓	↓	↓	↓	↓	
5	↓	↓	↓	↓	↓	↓	
6	↓	↓	↓	↓	↓	↓	
7	↓	↓	↓	↓	↓	↓	
8	↓	↓	↓	↓	↓	↓	
9	off	off	.01	off	off	off	.01
10	off	off	.04	off	off	off	.04
11	off	off	.04	off	off	off	.04
12			SYSTEM off				
13	↓	↓	↓	↓	↓	↓	
14	↓	↓	↓	↓	↓	↓	
15	↓	↓	↓	↓	↓	↓	
16	↓	↓	↓	↓	↓	↓	
17	↓	↓	↓	↓	↓	↓	
18	↓	↓	↓	↓	↓	↓	
19	↓	↓	↓	↓	↓	↓	
20	↓	↓	↓	↓	↓	↓	
21	↓	↓	↓	↓	↓	↓	
22	↓	↓	↓	↓	↓	↓	
23	↓	↓	↓	↓	↓	↓	
24	↓	↓	↓	↓	↓	↓	
25	↓	↓	↓	↓	↓	↓	
26	↓	↓	↓	↓	↓	↓	
27	↓	↓	↓	↓	↓	↓	
28	↓	↓	↓	↓	↓	↓	
29	↓	↓	↓	↓	↓	↓	
30	↓	↓	↓	↓	↓	↓	
31	↓	↓	↓	↓	↓	↓	

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No	
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No			
Notes: NO CAMPERs OR ACTIVITY IN JANUARY 23		PRINTED NAME: Fred Jensen	DATE: 2-1-23
		SIGNATURE: [Signature]	CERT #: 0
		PHONE #: (541) 832-2202	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Fir Point Bible Conference

ID #: OR4192108

WTP-: WTP-A

Month/year:

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			SYSTEM OFF					
2/								
3/								
4/								
5/								
6/								
7/								
8/								
9/	.41	210	86.1	9.8	7.60	48	Yes	
10/	.44	210	92.4	9.4	7.64	48	Yes	
11/	.44	210	92.4	10.1	7.61	45	Yes	
12/			SYSTEM OFF					
13/								
14/								
15/								
16/								
17/								
18/								
19/								
20/								
21/								
22/								
23/								
24/								
25/								
26/								
27/								
28/								
29/								
30/								
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf