

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane
Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: 4-23

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			System off				
2							
3							
4	off	off	.67	off	off	off	.67
5	off	off	.66	off	off	off	.66
6	off	off	.78	off	off	off	.78
7			System off				
8							
9							
10							
11							
12							
13	off	off	.02	off	off	off	.02
14	off	off	.02	off	off	off	.02
15			System off				
16							
17							
18							
19							
20	off	off	.02	off	off	off	.02
21	off	off	.01	off	off	off	.01
22	off	off	.02	off	off	off	.02
23	off	off	.02	off	off	off	.02
24			System off				
25							
26							
27							
28							
29							
30							
31							

RECEIVED
MAY 03 2023
Certification
Drinking Water Services

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes: pH measured 4-6 System off 4-6 High Turbidity	PRINTED NAME: Fred Jensen	DATE: 5-1-23
	SIGNATURE: <i>[Signature]</i>	CERT #: <i>[Signature]</i>
	PHONE #: (541) 832-2202	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

Fir Point Bible Conference		ID #: OR4192108	WTP:- WTP-A	Month/year: 4-23				
Date / Time	Minimum Cl ₂ Residual at User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			System off					
2/								
3/								
4/	.37	210	77.7	9.1	7.67	48	yes	
5/	.42	210	88.2	9.3	7.65	48	yes	
6/	.64	210	134.4	8.8	6.74	37	yes	
7/			System off					
8/								
9/								
10/								
11/								
12/								
13/	.78	210	163.8	9.3	6.68	48	yes	
14/	.70	210	147.0	10.3	6.79	49	yes	
15/			System off					
16/								
17/								
18/								
19/								
20/	.66	210	138.6	10.8	6.54	31	yes	
21/	.65	210	136.5	10.7	6.82	35	yes	
22/	.65	210	136.5	10.6	6.84	35	yes	
23/	.64	210	134.4	10.6	6.84	36	yes	
24/			System off					
25/								
26/								
27/								
28/								
29/								
30/								
31/								

RECEIVED
 MAY 03 2023
 Certification
 Drinking Water Services

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf