

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: 8-23

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			SYSTEM off	off			
2	off	off	.01	off	off	off	.01
3	off	off	.01	off	off	off	.01
4	off	off	.01	off	off	off	.01
5			SYSTEM off				
6							
7							
8							
9							
10	off	off	.01	off	off	off	.01
11	off	off	.01	off	off	off	.01
12	off	off	.01	off	off	off	.01
13			SYSTEM off				
14							
15							
16							
17							
18							
19							
20							
21							
22							
23	off	off	.01	off	off	off	.01
24	off	off	.01	off	off	off	.01
25	off	off	.01	off	off	off	.01
26	off	off	.01	off	off	off	.01
27			SYSTEM off				
28							
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes:		PRINTED NAME: Fred Jensen	DATE: 9-1-23
		SIGNATURE: [Signature]	CERT #: 0
		PHONE #: (541) 832-2202	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Fir Point Bible Conference ID #: OR4192108 WTP-: WTP-A Month/year: 8 - 23

Date / Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			SYSTEM off					
2/	.39	210	81.9	23.6	7.33	16	Yes	
3/	.46	210	96.6	23.3	7.38	16	Yes	
4/	.56	210	117.6	23.1	7.34	16	Yes	
5/			SYSTEM off					
6/								
7/								
8/								
9/								
10/	.46	210	96.6	23.8	7.37	16	Yes	
11/	.55	210	115.5	23.8	7.34	16	Yes	
12/	.55	210	115.5	23.7	7.35	16	Yes	
13/			SYSTEM off					
14/								
15/								
16/								
17/								
18/								
19/								
20/								
21/								
22/								
23/	.39	210	81.9	25.5	7.35	14	Yes	
24/	.40	210	84.0	22.1	7.48	18	Yes	
25/	.49	210	102.9	23.3	7.55	17	Yes	
26/	.55	210	115.5	24.2	7.48	15	Yes	
27/			SYSTEM off					
28/								
29/								
30/								
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf