



OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane
Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4182108 WTP:-WTP-A Month/Year: 11-23

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			System off				
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16	off	off	.01	off	off	off	.01
17	off	off	.01	off	off	off	.01
18			System off	Storm			
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes: 	PRINTED NAME: Fred Jensen	DATE: 12-1-23
	SIGNATURE: 	CERT #: 0
	PHONE #: (541) 832-2202	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Fir Point Bible Conference

ID #: OR4192108

WTP: WTP-A

Month/year: 11-23

Date / Time	Minimum Cl ₂ Residual at User (C) [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp [°C]	pH	Required CT Use tables	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1/			System off					
2/								
3/								
4/								
5/								
6/								
7/								
8/								
9/								
10/								
11/								
12/								
13/								
14/								
15/								
16/	.46	210	90.6	13.7	7.57	35	Yes	
17/	.53	210	111.3	12.8	7.48	36	Yes	
18/			System off		Storm			
19/								
20/								
21/								
22/								
23/								
24/								
25/								
26/								
27/								
28/								
29/								
30/								
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013. Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf