

OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP--WTP-A Month/Year: 1-24

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	off	off	.01	off	off	off	.01
2	off	off	.01	off	off	off	.01
3			System off	off			
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20	off	off	.01	off	off	off	.01
21			System off	Storm conditions			
22							
23	off	off	.02	off	off	off	.02
24			System off	Storming			
25	off	off	.01	off	off	off	.02
26			System off	Storm			
27							
28							
29	off	off	.27	off	off	off	.27
30			System off	Storm			
31							

RECEIVED
FEB 2 2024
Certification
Drinking Water Services

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No	All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:		PRINTED NAME: Fred Jensen	DATE: 2-1-24
		SIGNATURE: <i>[Signature]</i>	CERT #: <i>[Signature]</i>
		PHONE #: (541) 832-2202	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Date / Time	Minimum Cl ₂ Residual at User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/	.39	210	81.9	10.6	7.59	44	yes	
2/	.40	210	84	10.6	7.29	39	yes	
3/			System off					
4/								
5/								
6/								
7/								
8/								
9/								
10/								
11/								
12/								
13/								
14/								
15/								
16/								
17/								
18/								
19/								
20/	.40	210	84	9.6	7.57	46	yes	
21/			System off	Storm	conditions			
22/								
23/	.40	210	84	9.7	7.56	46	yes	
24/			off	Storming				
25/	.56	210	117.6	10.3	7.54	44	yes	
26/			System off	Storm				
27/								
28/								
29/	.44	210	92.4	10.1	7.55	44	yes	
30/			System off					
31/								

RECEIVED
 FEB 2 2024
 Certification
 Drinking Water Services

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf