

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: 2-24

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			SYSTEM off				
2							
3							
4							
5							
6							
7							
8							
9	off	off	.02	off	off	off	.02
10	off	off	.02	off	off	off	.02
11	off	off	.02	off	off	off	.02
12			SYSTEM off				
13							
14							
15							
16							
17							
18							
19							
20							
21							
22	off	off	.01	off	off	off	.01
23	off	off	.02	off	off	off	.02
24	off	off	.01	off	off	off	.01
25			SYSTEM off				
26							
27							
28							
29							
30	~~~~~						
31	~~~~~						

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes/No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes/No	Yes/No	Yes/No
Notes:		PRINTED NAME: Fred Jensen	
		SIGNATURE: [Signature]	DATE: 3-1-24
		PHONE #: (541) 832-2202	CERT #: [Symbol]

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

MAR 04 2024

Fir Point Bible Conference ID #: OR4192108 WTP:- WTP-A Month/year: 2-24 Certification Drinking Water Services

Date / Time	Minimum Cl ₂ Residual at User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			System off					
2/								
3/								
4/								
5/								
6/								
7/								
8/								
9/	.45	210	94.5	9.8	7.59	46	yes	
10/	.58	210	121.8	9.5	7.34	43	yes	
11/	.64	210	134.4	9.7	7.34	43	yes	
12/		System off						
13/								
14/								
15/								
16/								
17/								
18/								
19/								
20/								
21/								
22/	.50	210	105	10.3	7.33	41	yes	
23/	.50	210	105	10.5	7.35	41	yes	
24/	.55	210	115.5	10.3	7.34	41	yes	
25/		System off						
26/								
27/								
28/								
29/								
30/								
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013. Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf