

APR 09 2024

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP-:WTP-A Month/Year: 3-24

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			SYSTEM off				
2	↓	↓	↓	↓	↓	↓	↓
3	↓	↓	↓	↓	↓	↓	↓
4	↓	↓	↓	↓	↓	↓	↓
5	↓	↓	↓	↓	↓	↓	↓
6	↓	↓	↓	↓	↓	↓	↓
7	↓	↓	↓	↓	↓	↓	↓
8	↓	↓	↓	↓	↓	↓	↓
9	↓	↓	↓	↓	↓	↓	↓
10	↓	↓	↓	↓	↓	↓	↓
11	↓	↓	↓	↓	↓	↓	↓
12	↓	↓	↓	↓	↓	↓	↓
13	↓	↓	↓	↓	↓	↓	↓
14	↓	↓	↓	↓	↓	↓	↓
15	↓	↓	↓	↓	↓	↓	↓
16	↓	↓	↓	↓	↓	↓	↓
17	off	off	.15	off	off	off	.15
18	off	off	.31	off	off	off	.31
19	off	off	.27	off	off	off	.27
20	off	off	.36	off	off	off	.36
21			SYSTEM off				
22	↓	↓	↓	↓	↓	↓	↓
23	↓	↓	↓	↓	↓	↓	↓
24	↓	↓	↓	↓	↓	↓	↓
25	↓	↓	↓	↓	↓	↓	↓
26	↓	↓	↓	↓	↓	↓	↓
27	↓	↓	↓	↓	↓	↓	↓
28	↓	↓	↓	↓	↓	↓	↓
29	↓	↓	↓	↓	↓	↓	↓
30	↓	↓	↓	↓	↓	↓	↓
31	↓	↓	↓	↓	↓	↓	↓

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: SHUT DOWN DUE TO RAPID SNOW MELT & RUN OFF.		PRINTED NAME: FRED JOHNSON	DATE: 4-4-24
		SIGNATURE: [Signature]	CERT #: [Signature]
		PHONE #: (541) 832-2200	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

APR 09 2024

Fir Point Bible Conference

ID #: OR4192108

WTP: WTP-A

Month/year: 3-24

DWP-DMCE

Date / Time	Minimum Cl ₂ Residual at User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			SYSTEM off					
2/								
3/								
4/								
5/								
6/								
7/								
8/								
9/								
10/								
11/								
12/								
13/								
14/								
15/								
16/								
17/	.68	210	142.8	9.6	7.68	49	Yes	
18/	.64	210	134.4	9.6	7.54	48	Yes	
19/	.64	210	134.4	9.8	7.52	48	Yes	
20/	.62	210	130.2	10.5	7.52	45	Yes	
21/			SYSTEM off					
22/								
23/								
24/								
25/								
26/								
27/								
28/								
29/								
30/								
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf