

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: 4 - 24

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			System off				RECEIVED
2							
3							MAY 06 2024
4							Certification Drinking Water Services
5							
6							
7							
8	off	off	.01	off	off	off	.01
9	off	off	.02	off	off	off	.02
10	off	off	.02	off	off	off	.02
11	off	off	.01	off	off	off	.01
12			System off				
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23	off	off	.01	off	off	off	.01
24	off	off	.01	off	off	off	.01
25			System off				
26							
27							
28							
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Notes:		PRINTED NAME: Fred Jensen	DATE: 5-2-24
		SIGNATURE: <i>[Signature]</i>	CERT #: <i>[Signature]</i>
		PHONE #: (541) 832-2202	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Fir Point Bible Conference

ID #: OR4192108

WTP: WTP-A

Month/year: 4-24

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			System off					
2/								
3/								
4/								
5/								
6/								
7/								
8/	.60	210	126	11.6	7.35	39	yes	
9/	.54	210	113.4	11.7	7.31	38	yes	
10/	.56	210	117.6	11.7	7.27	37	yes	
11/	.56	210	117.6	12.6	7.26	34	yes	
12/			System off					
13/								
14/								
15/								
16/								
17/								
18/								
19/								
20/								
21/								
22/								
23/	.60	210	126	12.5	7.42	37	yes	
24/	.60	210	126	14.5	7.36	30	yes	
25/			System off					
26/								
27/								
28/								
29/								
30/								
31/								

RECEIVED

MAY 16 2024

Certification Drinking Water Services

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf