

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membran Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP--:WTP-A Month/Year: 5-24

Table with 8 columns: DAY, 12 AM [NTU], 4 AM [NTU], 8 AM [NTU], NOON [NTU], 4 PM [NTU], 8 PM [NTU], Highest Reading of the Day [NTU]. Rows 1-31 contain handwritten data including 'off', '0.01', '0.02', and 'System off'.

Summary section with 'Slow Sand/Membrane/DE Filtration/Unfiltered' and 'Monthly Summary (Answer Yes or No)'. Includes checkboxes for '95% of daily turbidity readings <= 1 NTU?' and 'CT's met everyday?'. Includes fields for 'PRINTED NAME: Fred Jensen', 'SIGNATURE: [Signature]', 'DATE: 6-1-24', 'PHONE #: (541) 832-2202', and 'CERT #: 0'.

1 Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. 2 Filtered systems only.

Fir Point Bible Conference ID #: OR4192108 WTP-: WTP-A Month/year: 5-24

Date / Time	Minimum Chlorine Residual at User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			system off					
2/								
3/								
4/								
5/								
6/								
7/								
8/								
9/								
10/								
11/								
12/								
13/								
14/								
15/	.63	210	132.3	15.9	7.59	30	yes	
16/	.63	210	132.3	17.4	7.45	26	yes	
17/			system off					
18/								
19/	.64	210	134.4	16.6	7.34	26	yes	
20/			system off					
21/	6.4	210	134.4	17.4	7.37	25	yes	
22/	.56	210	117.6	17.2	7.35	25	yes	
23/	.52	210	109.2	17.5	7.42	25	yes	
24/			system off					
25/	.64	210	134.4	16.3	7.41	27	yes	
26/	.61	210	128.1	17.3	7.42	26	yes	
27/	.60	210	126	16.9	7.40	27	yes	
28/			system off					
29/								
30/								
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf