

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP--:WTP-A Month/Year: 6-24

| DAY | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the Day <sup>1</sup> [NTU] |
|-----|-------------|------------|------------|------------|------------|------------|---|
| 1   |             |            | SYSTEM off |            |            |            |   |
| 2   | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 3   | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 4   | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 5   | off         | off        | .01        | off        | off        | off        | .01   |
| 6   | off         | off        | .01        | off        | off        | off        | .01   |
| 7   |             |            | SYSTEM off |            |            |            |   |
| 8   | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 9   | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 10  | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 11  | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 12  | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 13  | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 14  | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 15  | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 16  | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 17  | off         | off        | .01        | off        | off        | off        | .01   |
| 18  | off         | off        | .01        | off        | off        | off        | .01   |
| 19  | off         | off        | .01        | off        | off        | off        | .01   |
| 20  | off         | off        | .01        | off        | off        | off        | .01   |
| 21  |             |            | SYSTEM off |            |            |            |   |
| 22  | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 23  | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 24  | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 25  | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 26  | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 27  | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 28  | ↓           | ↓          | ↓          | ↓          | ↓          | ↓          |   |
| 29  | off         | off        | .01        | off        | off        | off        | .01   |
| 30  | off         | off        | .01        | off        | off        | off        | .01   |
| 31  |             |            |            |            |            |            |   |

RECEIVED  
JUL 05 2024  
Certification Drinking Water Services

|   |   |   |   |
|---|---|---|---|
| Slow Sand/Membrane/DE Filtration/Unfiltered           |   | Monthly Summary (Answer Yes or No)                              |   |
| 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> | <input checked="" type="radio"/> Yes / <input type="radio"/> No | CT's met everyday? (see back)                                   | All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l?         |
| All daily turbidity readings ≤ 5 NTU?                 | <input checked="" type="radio"/> Yes / <input type="radio"/> No | <input checked="" type="radio"/> Yes / <input type="radio"/> No | <input checked="" type="radio"/> Yes / <input type="radio"/> No |
| Notes:  |   | PRINTED NAME: Fred Jensen                                       | DATE: 7-1-24  |
|   |   | SIGNATURE: [Signature]  | CERT #: [Signature]   |
|   |   | PHONE #: ( )  |   |

<sup>1</sup>Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup>Filtered systems only.

Fir Point Bible Conference

ID #: OR4192108

WTP-: WTP-A

Month/year: 6-24

| Date / Time | Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup> | Contact Time (T) | Actual CT  | Temp | pH   | Required CT | CT Met? <sup>3</sup> | Peak Hourly Demand Flow |
|-------------|---|------------------|------------|------|------|-------------|----------------------|-------------------------|
|             | [ppm or mg/L]   | [minutes]        | CXT        | [°C] |      | Use tables  | Yes / No             | [GPM]                   |
| 1/          |   |                  | System off |      |      |             |                      |                         |
| 2/          |   |                  |            |      |      |             |                      |                         |
| 3/          |   |                  |            |      |      |             |                      |                         |
| 4/          |   |                  |            |      |      |             |                      |                         |
| 5/          | .42   | 210              | 86.2       | 18.3 | 7.34 | 23          | Yes                  |                         |
| 6/          | .56   | 210              | 117.6      | 18.7 | 7.39 | 23          | Yes                  |                         |
| 7/          |   |                  | System off |      |      |             |                      |                         |
| 8/          |   |                  |            |      |      |             |                      |                         |
| 9/          |   |                  |            |      |      |             |                      |                         |
| 10/         |   |                  |            |      |      |             |                      |                         |
| 11/         |   |                  |            |      |      |             |                      |                         |
| 12/         |   |                  |            |      |      |             |                      |                         |
| 13/         |   |                  |            |      |      |             |                      |                         |
| 14/         |   |                  |            |      |      |             |                      |                         |
| 15/         |   |                  |            |      |      |             |                      |                         |
| 16/         |   |                  |            |      |      |             |                      |                         |
| 17/         | .41   | 210              | 86.1       | 20.1 | 7.41 | 21          | Yes                  |                         |
| 18/         | .47   | 210              | 98.7       | 19.2 | 7.42 | 22          | Yes                  |                         |
| 19/         | .65   | 210              | 136.5      | 18.7 | 7.42 | 24          | Yes                  |                         |
| 20/         | .54   | 210              | 113.4      | 18.5 | 7.39 | 23          | Yes                  |                         |
| 21/         |   |                  | System off |      |      |             |                      |                         |
| 22/         |   |                  |            |      |      |             |                      |                         |
| 23/         |   |                  |            |      |      |             |                      |                         |
| 24/         |   |                  |            |      |      |             |                      |                         |
| 25/         |   |                  |            |      |      |             |                      |                         |
| 26/         |   |                  |            |      |      |             |                      |                         |
| 27/         |   |                  |            |      |      |             |                      |                         |
| 28/         |   |                  |            |      |      |             |                      |                         |
| 29/         | .37   | 210              | 77.7       | 19.7 | 7.57 | 23          | Yes                  |                         |
| 30/         | .41   | 210              | 86.1       | 21.6 | 7.54 | 20          | Yes                  |                         |
| 31/         |   |                  |            |      |      |             |                      |                         |

RECEIVED

JUL 05 2024

Certification Drinking Water Services

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013 Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf)