

**OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems**

**System Name:** Fir Point Bible Conference **ID #:**OR4182108 **WTP-:**WTP-A **Month/Year:** 9-24

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	off	off	.01	off	off	off	.01
2			System off				
3							
4							RECEIVED
5							OCT 04 2024
6							
7							Certification Drinking Water Services
8							
9							
10	off	off	.01	off	off	off	.01
11	off	off	.01	off	off	off	.01
12	off	off	.01	off	off	off	.01
13			System off				
14							
15							
16							
17							
18							
19							
20							
21							
22							
23	off	off	.01	off	off	off	.01
24	off	off	.01	off	off	off	.01
25			System off				
26							
27							
28							
29							
30							
31							

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>	<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <input checked="" type="checkbox"/> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
Notes:	PRINTED NAME: Fred Jensen	
	SIGNATURE: <i>[Signature]</i>	DATE: 10-1-24
	PHONE #: (541) 832-2202	CERT #: <i>[Signature]</i>

<sup>1</sup>Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup>Filtered systems only.



Fir Point Bible Conference

ID #: OR4192108

WTP-: WTP-A

Month/year: 9-24

Date / Time	Minimum Cl <sub>2</sub> Residual at User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/	.65	210	136.5	23.6	7.43	17	yes	
2/			System off					
3/								
4/								
5/								
6/								
7/								
8/								
9/								
10/								
11/	.45	210	94.5	21.2	7.52	20	yes	
12/	.45	210	94.5	21.2	7.30	19	yes	
13/	.45	210	94.5	22.7	7.32	18	yes	
14/			System off					
15/								
16/								
17/								
18/								
19/								
20/								
21/								
22/								
23/	.32	210	67.2	19.9	7.42	22	yes	
24/	.34	210	71.4	19.9	7.34	22	yes	
25/			System off					
26/								
27/								
28/								
29/								
30/								
31/								

RECEIVED

OCT 04 2024

Corvallis Drinking Water Services

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013 Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf)