

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP--:WTP-A Month/Year: 11-24

Table with 8 columns: DAY, 12 AM [NTU], 4 AM [NTU], 8 AM [NTU], NOON [NTU], 4 PM [NTU], 8 PM [NTU], Highest Reading of the Day [NTU]. Rows 1-31. Handwritten data includes 'off', '.02', and 'SYSTEM off'.

Slow Sand/Membrane/DE Filtration/Unfiltered Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU? 2 Yes/No
All daily turbidity readings ≤ 5 NTU? Yes/No
CT's met everyday? (see back) Yes/No
All Cl2 residual at entry point ≥ 0.2 mg/l? Yes/No

Notes:
PRINTED NAME: Fred Jensen
SIGNATURE: [Signature]
DATE: 12-2-24
PHONE #: (541) 832-2202
CERT #: [Signature]

1 Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. 2 Filtered systems only.

RECEIVED
 DEC 05 2024
 Certification Drinking Water Services

Fir Point Bible Conference		ID #: OR4192108	WTP-: WTP-A	Month/year: 11 - 24				
Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			SYSTEM off					
2/								
3/								
4/								
5/	.38	210	79.8	14.7	7.33	30	yes	
6/	.38	210	79.8	13.8	7.48	34	yes	
7/	.65	210	136.5	13.8	7.48	34	yes	
8/			SYSTEM off					
9/								
10/								
11/								
12/								
13/								
14/								
15/								
16/								
17/								
18/								
19/								
20/								
21/								
22/								
23/								
24/								
25/								
26/								
27/								
28/								
29/								
30/								
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013. Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf