

**OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane
Diatomaceous Earth Filtration or Unfiltered Systems**

System Name: Fir Point Bible Conference **ID #:** OR4192108 **WTP-:** WTP-A **Month/Year:** 1-25-

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			System off				
2							
3							
4							
5							
6	off	off	.46	off	off	off	.46
7	off	off	.26	off	off	off	.26
8			System off				
9							
10							
11							
12							
13	off	off	.11	off	off	off	.11
14	off	off	.11	off	off	off	.11
15			System off Storage Tank full				
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28	off	off	.02	off	off	off	.02
29	off	off	.02	off	off	off	.02
30			System off				
31							

RECEIVED
FEB 05 2025
Certification Drinking Water Services

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: Fred Jensen	DATE: 2-1-25
	SIGNATURE: <i>[Signature]</i>	PHONE #: (541) 832-2202
	PHONE #: (541) 832-2202	CERT #: <i>[Symbol]</i>

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Fir Point Bible Conference

ID #: OR4192108

WTP: WTP-A

Month/year: 1-25

Date / Time	Minimum Cl ₂ Residual at User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			System off					
2/								
3/								
4/								
5/								
6/	.32	210	67.20	10.5	7.47	42	Yes	
7/	.37	210	77.7	11.3	7.46	39	Yes	
8/			System off					
9/								
10/								
11/								
12/								
13/	.53	210	114.3	10.1	7.59	44	Yes	
14/	.47	210	98.70	10.1	7.48	42	Yes	
15/			System off	Storage Tank			Full	
16/								
17/								
18/								
19/								
20/								
21/								
22/								
23/								
24/								
25/								
26/								
27/								
28/	.38	210	121.8	11.3	7.44	39	Yes	
29/	.48	210	100.8	10.2	7.45	42	Yes	
30/	.48	210	System off				Yes	
31/								

RECEIVED
 FEB 05 2025
 Certification Drinking Water Services

³ If Cl₂ at entry point < 0.2 mg/L OR CT not met, notify DWS within 24 hours. Revised October 2013. Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-elt-unfiltered.pdf