

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: 3-25

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			System off				
2	1	1	1	1	1	1	1
3	off	off	.01	off	off	off	.01
4	off	off	.31	off	off	off	.31
5	off	off	.34	off	off	off	.34
6	off	off	.24	off	off	off	.24
7			System off				
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24	off	off	.32	off	off	off	.32
25	off	off	.32	off	off	off	.32
26	off	off	.32	off	off	off	.32
27			System off				
28							
29							
30							
31							

RECEIVED
APR 08 2025
Continuation Drinking Water Services

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	Yes/No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	Yes/No	Yes/No	Yes/No
Notes:		PRINTED NAME: Fred Jensen	
		SIGNATURE: [Signature]	DATE: 4-2-25
		PHONE #: (541) 832-2202	CERT #: 0

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Fir Point Bible Conference

ID #: OR4192108

WTP: WTP-A

Month/year: 3-25

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ⁸	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ⁹	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1 /			System off					
2 /	1	1	1	1	1	1	1	
3 /	.30	210	63	10.7	7.49	42	yes	
4 /	.34	210	71.4	10.3	7.53	44	yes	
5 /	.34	210	71.4	10.4	7.44	42	yes	
6 /	.47	210	98.1	11.9	7.52	41	yes	
7 /	.51		system off					
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								
20 /								
21 /								
22 /								
23 /								
24 /	.41	210	86.1	10.2	7.3	41	yes	
25 /	.51	210	107.1	11.1	7.54	41	yes	
26 /	.45	210	94.5	10.7	7.56	44	yes	
27 /			system off					
28 /								
29 /								
30 /								
31 /								

⁸ If Cl₂ at entry point < 0.2 mg/L OR CT not met, notify DWS within 24 hours. Revised October 2013. Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-act-unfiltered.pdf

RECEIVED
APR 08 2025
Certification Drinking Water Services