

OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: **Fir Point Bible Conference** ID #: **OR4192108** WTP: **WTP-A** Month/Year: **4-25**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1			System off				
2							
3							
4							
5							
6	off	off	.34	off	off	off	.34
7	off	off	.34	off	off	off	.34
8			System off				
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24	off	off	.01	off	off	off	.01
25	off	off	.02	off	off	off	.02
26	off	off	.02	off	off	off	.02
27			System off				
28							
29							
30							
31							

RECEIVED
MAY 12 2025
Certification Drinking Water Services

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	☒ Yes / ☐ No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	☒ Yes / ☐ No	☒ Yes / ☐ No	☒ Yes / ☐ No
Notes:		PRINTED NAME: Fred Jensen	
		SIGNATURE: <i>[Signature]</i>	DATE: 5-5-25
		PHONE #: (541) 832-2202	CERT #: 7

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Fir Point Bible Conference

ID #: OR4192108

WTP: WTP-A

Month/year: 4-25

Date / Time	Minimum Cl ₂ Residual at User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/		System off						
2/								
3/								
4/								
5/								
6/	.34	210	71.4	11.9	7.56	42	yes	
7/	.34	210	71.4	12.4	7.56	38	yes	
8/			System off					
9/								
10/								
11/								
12/								
13/								
14/								
15/								
16/								
17/								
18/								
19/								
20/								
21/								
22/								
23/								
24/	.35	210	73.5	14.4	7.56	32	yes	
25/	.35	210	73.5	14.4	7.34	30	yes	
26/	.35	210	73.5	14.8	7.38	30	yes	
27/			System off					
28/								
29/								
30/								
31/								

RECEIVED

MAY 12 2025

Certification Drinking Water Services

³ If Cl₂ at entry point < 0.2 mg/L OR CT not met, notify DWS within 24 hours. Revised October 2013 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-att-unfiltered.pdf