

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: 5-25

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			System off				
2							
3							
4							
5							
6							
7							
8							
9							
10	off	off	.02	off	off	off	.02
11	off	off	.01	off	off	off	.01
12	off	off	.01	off	off	off	.01
13	off	off	.01	off	off	off	.01
14	off	off	.01	off	off	off	.01
15			System off				
16							
17							
18							
19							
20	off	off	.01	off	off	off	.01
21	off	off	.01	off	off	off	.01
22	off	off	.01	off	off	off	.01
23			System off				
24							
25							
26							
27							
28							
29							
30							
31							

RECEIVED
JUN 12 2025
Gentle Drinking Water Services

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² ☒ Yes ☐ No	CT's met everyday? (see back) ☒ Yes ☐ No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? ☒ Yes ☐ No
All daily turbidity readings ≤ 5 NTU? ☒ Yes ☐ No		
Notes:	PRINTED NAME: Fred Jensen	
	SIGNATURE: [Signature]	DATE: 6-1-25
	PHONE #: (541) 832-2202	CERT #: [Signature]

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

Fir Point Bible Conference

ID #: OR4192108

WTP: WTP-A

Month/year:

5-25

Date / Time	Minimum Cl ₂ ^{at} Residual at User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			System off					
2/								
3/								
4/								
5/								
6/								
7/								
8/								
9/								
10/	.54	210	113.4	15.8	7.36	27	yes	
11/	.55	210	115.5	17.3	7.24	25	yes	
12/	.60	210	126	17.8	7.35	25	yes	
13/	.60	210	126	16.8	7.35	26	yes	
14/	.62	210	130.2	16.3	7.42	27	yes	
15/			System off					
16/								
17/								
18/								
19/								
20/	.50	210	105	14.8	7.27	29	yes	
21/	.47	210	98.7	16.5	7.37	26	yes	
22/	.48	210	100.8	16.4	7.38	26	yes	
23/			System off					
24/								
25/								
26/								
27/								
28/								
29/								
30/								
31/								

RECEIVED

JUN 2 2025

Corvallis Drinking Water Services

³ If Cl₂ at entry point < 0.2 mg/L OR CT not met, notify DWS within 24 hours. Revised October 2013. Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-att-unfiltered.pdf