

RECEIVED

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane
Diatomaceous Earth Filtration or Unfiltered Systems

AUG 08 2025
DWF-DMCE

System Name: Fir Point Bible Conference ID #:OR4182108 WTP:-WTP-A Month/Year: 7-25

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			System off				
2	1	1	1	1	1	1	1
3	off	off	.01	off	off	off	.01
4	off	off	.01	off	off	off	.01
5			System off				
6	1	1	1	1	1	1	1
7	1	1	1	1	1	1	1
8	off	off	.01	off	off	off	.01
9	off	off	.01	off	off	off	.01
10	off	off	.01	off	off	off	.01
11	off	off	.01	off	off	off	.01
12	off	off	.01	off	off	off	.01
13			System off				
14	1	1	1	1	1	1	1
15	off	off	.01	off	off	off	.01
16	off	off	.01	off	off	off	.01
17	off	off	.01	off	off	off	.01
18	off	off	.01	off	off	off	.01
19	off	off	.01	off	off	off	.01
20			System off				
21	1	1	1	1	1	1	1
22	off	off	.01	off	off	off	.01
23			System off				
24	1	1	1	1	1	1	1
25	1	1	1	1	1	1	1
26	off	off	.01	off	off	off	.01
27	off	off	.01	off	off	off	.01
28	off	off	.01	off	off	off	.01
29			System off				
30	1	1	1	1	1	1	1
31	off	off	.01	off	off	off	.01

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	Yes / No	Yes / No	Yes / No
Notes:		PRINTED NAME: Fred Jensen	
		SIGNATURE: [Signature]	DATE: 8-1-25
		PHONE #: (541) 832-2202	CERT #: [Signature]

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Fir Point Bible Conference

ID #: OR4192108

WTP-: WTP-A

Month/year:

RECEIVED

AUG 08 2025

7-25

Date / Time	Minimum Chlorine Residual at User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			System off					
2/	1	1	1	1	1	1	1	
3/	.44	210	92.4	22.3	7.34	18	Yes	
4/	.43	210	90.3	22.7	7.47	18	Yes	
5/			System off					
6/	1	1	1	1	1	1	1	
7/	1	1	1	1	1	1	1	
8/	.35	210	73.5	21.6	7.47	22	Yes	
9/	.37	210	77.7	22.5	7.51	19	Yes	
10/	.45	210	94.5	21.2	7.57	20	Yes	
11/	.45	210	94.5	22.6	7.57	19	Yes	
12/	.45	210	94.5	22.8	7.47	18	Yes	
13/			System off					
14/	1	1	1	1	1	1	1	
15/	.30	210	63	21.5	7.54	20	Yes	
16/	.34	210	71.4	24.2	7.37	15	Yes	
17/	.40	210	84	23.9	7.59	17	Yes	
18/	.44	210	92.4	23.7	7.42	17	Yes	
19/	.44	210	92.4	24.3	7.54	16	Yes	
20/			System off					
21/	1	1	1	1	1	1	1	
22/	.30	210	63	23.5	7.54	17	Yes	
23/			System off					
24/	1	1	1	1	1	1	1	
25/	1	1	1	1	1	1	1	
26/	.30	210	63	22.5	7.54	19	Yes	
27/	.39	210	81.9	23.5	7.65	20	Yes	
28/	.45	210	94.5	23.7	7.45	17	Yes	
29/			System off					
30/	1	1	1	1	1	1	1	
31/	.45	210	94.5	24.3	7.47	15	Yes	

³ If Cl₂ at entry point < 0.2 mg/L OR CT not met, notify DWS within 24 hours. Revised October 2013 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alk-unfiltered.pdf