

RECEIVED

SEP 04 2025

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane
Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: 8-25

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	.01	off	off	off	.01
2	off	off	.01	off	off	off	.01
3	off	off	.01	off	off	off	.01
4			System off				
5							
6							
7	off	off	.01	off	off	off	.01
8	off	off	.01	off	off	off	.01
9			System off				
10							
11							
12	off	off	.01	off	off	off	.01
13	off	off	.01	off	off	off	.01
14	off	off	.01	off	off	off	.01
15	off	off	.01	off	off	off	.01
16			System off				
17							
18							
19							
20							
21							
22							
23							
24							
25							
26	off	off	.01	off	off	off	.01
27	off	off	.01	off	off	off	.01
28			System off				
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered

95% of daily turbidity readings $\leq$ 1 NTU? ² Yes / No
All daily turbidity readings $\leq$ 5 NTU? Yes / No

Notes:

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)
Yes / No

All Cl₂ residual at entry point $\geq$ 0.2 mg/l?
Yes / No

PRINTED NAME: Fred Jensen

SIGNATURE: [Signature]

DATE: 9-1-25

PHONE #: (541) 832-2202

CERT #: 0

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

RECEIVED
SEP 04 2025

Certification Drinking Water Services

Fir Point Bible Conference ID #: OR4192108 WTP: WTP-A Month/year: 8-25								
Date / Time	Minimum Cl ₂ Residual at User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/	.46	210	96.6	24.3	7.65	17	yes	
2/	.45	210	94.5	23.9	7.47	17	yes	
3/	.42	210	88.2	23.9	7.44	17	yes	
4/			System off					
5/								
6/								
7/	.27	210	56.7	23.8	7.54	17	yes	
8/	.38	210	79.8	24.4	7.51	16	yes	
9/			System off					
10/								
11/								
12/	.34	210	71.4	23.2	7.52	17	yes	
13/	.47	210	98.7	24.1	7.65	17	yes	
14/	.47	210	98.7	23.8	7.65	18	yes	
15/	.47	210	98.7	25.2	7.65	15	yes	
16/			System off					
17/								
18/								
19/								
20/								
21/								
22/								
23/								
24/								
25/								
26/	.28	210	58.8	25.4	7.64	15	yes	
27/	.46	210	96.6	25.3	7.57	15	yes	
28/			System off					
29/								
30/								
31/								

³ If Cl₂ at entry point < 0.2 mg/L OR CT not met, notify DWS within 24 hours. Revised October 2013 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-att-unfiltered.pdf