

RECEIVED

NOV 07 2005

Certified Drinking Water Services

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: 10-25

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1			SYSTEM off				
2							
3							
4							
5							
6	off	off	.01	off	off	off	.01
7	off	off	.01	off	off	off	.01
8			System off				
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20	off	off	.01	off	off	off	.01
21	off	off	.01	off	off	off	.01
22	off	off	.01	off	off	off	.01
23			SYSTEM off				
24							
25							
26							
27							
28							
29	off	off	.01	off	off	off	.01
30	off	off	.01	off	off	off	.01
31			SYSTEM off				

Slow Sand/Membrane/DE Filtration/Unfiltered

 95% of daily turbidity readings $\leq$ 1 NTU? ²
 All daily turbidity readings $\leq$ 5 NTU?

 Yes / No
 Yes / No

Notes:

Monthly Summary (Answer Yes or No)

 CT's met everyday?
 (see back)
 Yes / No

 All Cl₂ residual at entry point $\geq$ 0.2 mg/l?
 Yes / No

PRINTED NAME: Fred Jensen

SIGNATURE: [Signature]

DATE: 11-1-25

PHONE #: (541) 832-2202

CERT #: [Signature]

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

RECEIVED
NOV 07 2025
Certification Drinking Water

Fir Point Bible Conference ID #: OR4192108 WTP: WTP-A Month/year: 10-25

Date / Time	Minimum Cl ₂ Residual at User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			System off					
2/								
3/								
4/								
5/								
6/	.34	210	71.4	19.3	7.62	24	yes	
7/	.34	210	71.4	19.3	7.59	23	yes	
8/			System off					
9/								
10/								
11/								
12/								
13/								
14/								
15/								
16/								
17/								
18/								
19/								
20/	.32	210	67.2	16.3	7.39	26	yes	
21/	.33	210	69.3	16.4	7.38	26	yes	
22/	.34	210	71.4	15.4	7.38	27	yes	
23/			System off					
24/								
25/								
26/								
27/								
28/	.59	210	123.9	15.1	7.29	27	yes	
29/	.55	210	115.5	14.5	7.30	29	yes	
30/			System off					
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013. Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf