

RECEIVED

FEB 09 2026
 Certification of Drinking Water Services

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: 1-26

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1			System off				
2							
3							
4							
5							
6							
7							
8							
9	off	off	.01	off	off	off	.01
10	off	off	.01	off	off	off	.01
11	off	off	.01	off	off	off	.01
12			System off				
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26	off	off	.01	off	off	off	.01
27	off	off	.01	off	off	off	.01
28	off	off	.01	off	off	off	.01
29			System off				
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes:	PRINTED NAME: Fred Jensen	
	SIGNATURE: <i>[Signature]</i>	DATE: 2-1-26
	PHONE #: (541) 832-2202	CERT #: <i>[Symbol]</i>

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

RECEIVED
 FEB 09 2026
 Certification Drinking Water

Fir Point Bible Conference		ID #: OR4192108	WTP: WTP-A	Month/year:	1 - 2			
Date / Time	Minimum Cl ₂ Residual at User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ^a	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/								
2/								
3/								
4/								
5/								
6/								
7/								
8/								
9/	.40	210	84	10.8	6.62	31	yes	
10/	.40	216	84	10.8	6.63	31	yes	
11/	.40	210	84	10.7	6.63	31	yes	
12/								
13/								
14/								
15/								
16/								
17/								
18/								
19/								
20/								
21/								
22/								
23/								
24/								
25/								
26/	.38	210	79.8	10.7	6.68	31	yes	
27/	.38	210	79.8	10.7	6.68	31	yes	
28/	.60	210	126	10.6	6.69	31	yes	
29/								
30/								
31/								

^a If Cl₂ at entry point < 0.2 mg/L OR CT not met, notify DWS within 24 hours. Revised October 2013. Download form at: public.health.oregon.gov/healthyEnvironments/DrinkingWater/Monitoring/Documents/turb-elt-unfiltered.pdf