

OHA - Drinking Water Services - Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:WTP-A Month/Year: 2-26

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1				System off			
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18	off	off	.01	off	off	off	.01
19	off	off	.01	off	off	off	.01
20	off	off	.01	off	off	off	.01
21	off	off	.01	off	off	off	.01
22			System on				
23							
24							
25							
26							
27							
28							
29							
30							
31							

RECEIVED  
MAR 03 2026  
Clatsop County Drinking Water Services

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> Yes/No	CT's met everyday? (see back) Yes/No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? Yes/No
All daily turbidity readings ≤ 5 NTU? Yes/No		
Notes:	PRINTED NAME: Fred JENSON	DATE: 3-3-26
	SIGNATURE: [Signature]	CERT #: [Signature]
	PHONE #: (541) 2202	

<sup>1</sup>Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup>Filtered systems only.

Fire Point Bible Conference

ID #: OR4192108

WTP: WTP-A

Month/year: 2-26

Date / Time	Minimum Chlorine Residual at User (C) [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp [°C]	pH	Required CT Use tables	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1/								
2/								
3/								
4/								
5/								
6/								
7/								
8/								
9/								
10/								
11/								
12/								
13/								
14/								
15/								
16/								
17/								
18/	.40	210	84	10.4	7.34	41	Yes	
19/	.42	210	88.2	10.5	7.35	41	Yes	
20/	.54	210	113.4	10.5	7.33	41	Yes	
21/	.50	210	105	10.5	7.34	41	Yes	
22/								
23/								
24/								
25/								
26/								
27/								
28/								
29/								
30/								
31/								

RECEIVED  
MAR 09 2026  
Clackamas Drinking Water Services

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L OR CT not met, notify DWS within 24 hours. Revised October 2013. Download form at: [public.health.oregon.gov/healthyEnvironments/DrinkingWater/Monitoring/Documents/turb-elt-unfiltered.pdf](http://public.health.oregon.gov/healthyEnvironments/DrinkingWater/Monitoring/Documents/turb-elt-unfiltered.pdf)