

OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: JAN 2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1			System		off		
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							✓
13	off	off	.01	off	off	off	.01
14	off	off	.01	off	off	off	.01
15			System	off			
16							
17							
18							
19							
20							
21							
22							
23							
24							
25	off	off	.01	off	off	off	.01
26	off	off	.01	off	off	off	.01
27			System	off			
28							
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> Yes/No All daily turbidity readings ≤ 5 NTU? Yes/No Notes:	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) Yes/No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? Yes/No
RECEIVED FEB 4 2021 Data Mgmt & Compliance	PRINTED NAME: Fred Jensen	
	SIGNATURE: [Signature]	DATE: 2-1-21
	PHONE #: (541) 832-2202	CERT #: [Signature]

<sup>1</sup>Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup>Filtered systems only.

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			System	off				
2/								
3/								
4/								
5/								
6/								
7/								
8/								
9/								
10/								
11/								
12/								
13/	.60	210	126.0	11.3	7.56	41	Yes	
14/	.65	210	136.5	12.6	7.55	38	Yes	
15/			System	off				
16/								
17/								
18/								
19/								
20/								
21/								
22/								
23/								
24/								
25/	.59	210	123.9	9.7	7.58	46	Yes	
26/	.64	210	134.4	10.2	7.58	44	Yes	
27/			System	off				
28/								
29/								
30/								
31/								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013. Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf)

RECEIVED  
FEB 4 2021