

OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: 5-21

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1			System off				
2							
3							
4							
5							
6							
7							
8							
9							
10							
11	off	off	.01	off	off	off	.01
12	off	off	.02	off	off	off	.02
13	off	off	.02	off	off	off	.02
14			System off				
15							
16							
17							
18							
19							
20							
21							
22							
23							
24	off	off	.01	off	off	off	.01
25	off	off	.02	off	off	off	.02
26	off	off	.02	off	off	off	.02
27			System off				
28							
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No Notes: JUN 03 2021 Data Mgmt & Compliance Drinking Water Program	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
PRINTED NAME: Fred Jensen		DATE: 6-1-21
SIGNATURE: <i>[Signature]</i>		PHONE #: (503) 832-2202
CERT #: <i>[Signature]</i>		CERT #: <i>[Signature]</i>

<sup>1</sup>Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup>Filtered systems only.

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			SYSTEM off					
2/								
3/								
4/								
5/								
6/								
7/								
8/								
9/								
10/								
11/	.75	210	157.5	16.8	7.52	28	yes	
12/	.58	210	121.8	16.4	7.52	28	yes	
13/	.58	210	121.8	15.2	7.34	27	yes	
14/			SYSTEM off					
15/								
16/								
17/								
18/								
19/								
20/								
21/								
22/								
23/								
24/	.78	210	163.8	15.8	7.61	30	yes	
25/	.75	210	157.5	17.2	7.57	27	yes	
26/	.75	210	157.5	17.7	7.54	27	yes	
27/			SYSTEM off					
28/								
29/								
30/								
31/								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013 Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf)

RECEIVED  
JUN 03 2021