



OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: 7-21

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	.01	off	off	off	.01
2			System off				
3							
4							
5	off	off	.02	off	off	off	.02
6	off	off	.02	off	off	off	.02
7			System off				
8							
9							
10							
11	off	off	.02	off	off	off	.02
12	off	off	.02	off	off	off	.02
13			System off				
14							
15	off	off	.02	off	off	off	.02
16	off	off	.02	off	off	off	.02
17	off	off	.01	off	off	off	.01
18			System off				
19							
20							
21	off	off	.01	off	off	off	.01
22	off	off	.02	off	off	off	.02
23	off	off	.02	off	off	off	.02
24			System off				
25							
26							
27							
28	off	off	.02	off	off	off	.02
29	off	off	.02	off	off	off	.02
30	off	off	.01	off	off	off	.01
31	off	off	.02	off	off	off	.02

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes/No All daily turbidity readings ≤ 5 NTU? Yes/No	CT's met everyday? (see back) Yes/No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes/No
Notes: 	PRINTED NAME: Fred Jensen	
	SIGNATURE: 	DATE: 7-31-21
	PHONE #: (541) 832-2202	CERT #: 0

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Date / Time	Minimum Cl ₂ Residual at User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/	.60	210	126	23.5	7.56	18	yes	
2/			system off					
3/								
4/								
5/	.34	210	71.4	23.2	7.57	17	yes	
6/	.39	210	81.9	22.8	7.60	19	yes	
7/			system off					
8/								
9/								
10/								
11/	.37	210	7.77	22.7	7.40	18	yes	
12/	.60	210	126.0	23.8	7.53	18	yes	
13/			system off					
14/								
15/	.60	210	126.0	22.9	7.53	18	yes	
16/	.62	210	130.2	24.6	7.52	15	yes	
17/	.62	210	130.2	24.1	7.46	15	yes	
18/			system off					
19/								
20/								
21/	.48	210	100.8	22.9	7.57	19	yes	
22/	.54	210	113.4	23.8	7.52	17	yes	
23/	.54	210	113.4	23.7	7.48	16	yes	
24/			system off					
25/								
26/								
27/								
28/	.36	210	75.6	25.2	7.51	15	yes	
29/	.52	210	109.2	23.7	7.56	17	yes	
30/	.62	210	130.2	24.3	7.40	15	yes	
31/	.63	210	132.3	22.3	7.51	19	yes	

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013. Download form at:

RECEIVED
AUG 02 2021

