

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Linn

Conventional or Direct Filtration

Month/Year: Jun-25

System Name:	Cascade Pacific Pulp			ID#:	OR4192152		WTP : TP - A
Day	7 AM [NTU]	11 AM [NTU]	3 PM [NTU]	7 PM [NTU]	11 PM [NTU]	3 AM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.08	0.08	0.08	0.09	0.07	0.09	0.09
2	0.08	0.09	0.07	0.08	0.08	0.08	0.09
3	0.09	0.09	0.09	0.09	0.08	0.08	0.09
4	0.09	0.09	0.08	0.09	0.08	0.09	0.09
5	0.09	0.09	0.07	0.08	0.09	0.09	0.09
6	0.08	0.09	0.09	0.07	0.08	0.08	0.09
7	0.08	0.09	0.09	0.09	0.09	0.09	0.09
8	0.09	0.09	0.09	0.09	0.09	0.09	0.09
9	0.09	0.09	0.09	0.09	0.10	0.10	0.10
10	0.10	0.09	0.09	0.10	0.09	0.07	0.10
11	0.09	0.10	0.09	0.08	0.07	0.09	0.10
12	0.09	0.07	0.08	0.06	0.07	0.09	0.09
13	0.08	0.06	0.06	0.06	0.07	0.07	0.08
14	0.06	0.07	0.06	0.06	0.07	0.07	0.07
15	0.06	0.06	0.07	0.07	0.08	0.08	0.08
16	0.08	0.08	0.09	0.08	0.09	0.07	0.09
17	0.07	0.09	0.07	0.07	0.07	0.08	0.09
18	0.07	0.08	0.08	0.07	0.08	0.08	0.08
19	0.07	0.08	0.08	0.08	0.08	0.08	0.08
20	0.08	0.08	0.09	0.09	0.07	0.09	0.09
21	0.08	0.07	0.08	0.09	0.07	0.09	0.09
22	0.08	0.07	0.07	0.08	0.07	0.08	0.08
23	0.08	0.08	0.09	0.11	0.12	0.10	0.12
24	0.09	0.09	0.09	0.09	0.08	0.08	0.09
25	0.08	0.08	0.09	0.09	0.09	0.08	0.09
26	0.09	0.09	0.09	0.09	0.09	0.10	0.10
27	0.09	0.09	0.09	0.09	0.09	0.09	0.09
28	0.09	0.09	0.09	0.09	0.09	0.10	0.10
29	0.10	0.10	0.09	0.10	0.11	0.10	0.10
30	0.07	0.10	0.10	0.12	0.11	0.11	0.12
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:		PRINTED NAME: DARREL LUKARD SIGNATURE: [Signature] PHONE #: (541) 505-9169	
		DATE: 7-3-25 CERT #: 2853	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:

ID#: 41

Month/Year:

WTP - :

Disinfection *Giardia*
Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.22	80	97.6	18.7	7.18	23.3	YES	91.8
2	1.32	80	105.6	18.0	7.10	24.0	YES	109.8
3	1.32	80	105.6	18.3	7.05	23.1	YES	100.9
4	1.37	80	109.6	18.7	7.08	22.8	YES	88.4
5	1.55	80	124.0	18.5	7.11	23.9	YES	87.1
6	1.39	80	111.2	19.1	7.06	22.1	YES	91.4
7	1.41	80	112.8	21.1	7.01	19.0	YES	94.1
8	1.36	80	108.8	22.0	7.06	18.1	YES	92.5
9	1.42	80	113.6	22.0	7.14	18.8	YES	96.9
10	1.44	80	115.2	22.1	6.86	16.8	YES	93.6
11	1.47	80	117.6	21.6	6.81	17.2	YES	91.2
12	1.39	80	111.2	20.8	6.94	18.8	YES	92.3
13	1.45	80	116.0	19.3	7.00	21.5	YES	89.2
14	1.33	80	106.4	19.1	7.14	22.6	YES	88.3
15	1.35	80	108.0	19.0	6.90	20.9	YES	88.4
16	1.42	80	113.6	19.1	7.05	22.1	YES	91.1
17	1.35	80	108.0	19.7	7.06	21.1	YES	81.3
18	1.43	80	114.4	20.0	6.87	19.5	YES	82.8
19	1.35	80	108.0	19.8	7.05	20.9	YES	82.4
20	1.3	80	104.0	19.2	6.89	20.4	YES	83.8
21	1.39	80	111.2	18.9	7.13	23.0	YES	83.1
22	1.25	80	100.0	17.9	7.02	23.2	YES	81.8
23	1.38	80	110.4	17.7	7.16	25.2	YES	99.6
24	1.37	80	109.6	19.3	7.05	21.7	YES	103.6
25	1.41	80	112.8	20.0	7.15	21.6	YES	97.1
26	1.37	80	109.6	19.6	7.10	21.7	YES	94.2
27	1.4	80	112.0	20.8	6.94	18.9	YES	92.6
28	1.45	80	116.0	21.2	6.97	18.7	YES	90.2
29	1.42	80	113.6	21.5	7.04	18.7	YES	97.6
30	1.42	80	113.6	22.5	7.11	18.0	YES	96.2
31		80						

If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
dwp.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350