OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: Linn

Month/Year: Aug-25

System Name: Cascade Pacific Pulp ID#: OR4192152 WTP : TP - A

Day	7 AM [NTU]	11 AM [NTU]	3 PM [NTU]	7 PM [NTU]	11 PM [NTU]	3 AM [NTU]	Highest Reading of the Day [1] [NTU]
1	0.11	0.10	0.10	0.11	0.11	0.10	0.11
2	0.12	0.10	0.11	0.10	0.12	0.10	0.12
3	0.11	0.12	0.10	0.12	0.11	0.10	0.12
4	0.09	0.10	0.10	0.11	0.11	0.10	0.11
5	0.09	0.10	0.10	0.10	0.11	0.11	0.11
6	0.09	0.11	0.09	0.10	0.11	0.11	0.11
7	0.09	0.10	0.10	0.11	0.10	0.11	0.11
8	0.09	0.09	0.09	0.10	0.10	0.10	0.10
9	0.10	0.10	0.10	0.09	0.09	0.09	0.10
10	0.13	0.09	0.11	0.12	0.13	0.11	0.13
11	0.10	0.11	0.11	0.11	0.11	0.11	0.11
12	0.11	0.12	0.11	0.12	0.11	0.11	0.12
13	0.11	0.13	0.10	0.11	0.11	0.11	0.13
14	0.13	0.11	0.11	0.13	0.12	0.13	0.13
15	0.10	0.11	0.10	0.10	0.13	0.12	0.13
16	0.12	0.09	0.10	0.10	0.11	0.10	0.12
17	0.10	0.10	0.10	0.10	0.10	0.11	0.11
18	0.10	0.10	0.11	0.11	0.11	0.11	0.11
19	0.10	0.10	0.11	0.11	0.10	0.10	0.11
20	0.09	0.07	0.11	0.09	0.10	0.08	0.11
21	0.09	0.10	0.09	0.10	0.11	0.11	0.11
22	0.10	0.10	0.09	0.09	0.10	0.10	0.10
23	0.10	0.10	0.11	0.12	0.10	0.11	0.12
24	0.11	0.11	0.12	0.13	0.10	0.11	0.13
25	0.11	0.10	0.08	0.10	0.10	0.10	0.11
26	0.09	0.11	0.10	0.10	0.11	0.11	0.11
27	0.10	0.12	0.10	0.11	0.11	0.11	0.12
28	0.10	0.11	0.12	0.08	0.11	0.09	0.11
29	0.10	0.11	0.14	0.11	0.12	0.12	0.14
30	0.13	0.12	0.11	0.12	0.11	0.12	0.13
31	0.11	0.11	0.11	0.12	0.13	0.13	0.13

Conventional or Direct Filtration

95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No

All 4-hour turbidity readings ≤ 1 NTU? Yes / No

All turbidity readings < IFE[2] triggers Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: DARREL LOCKARD

SIGNATURE: [signature] DATE: 9/9/2025

PHONE #: (541) 505-9968 CERT #: 2853

[1] Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. [2] IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	ID#: 41	Month/Year:	WTP - :
			Disinfection *Giardia* Log Inactive: 1

Date / Time	Minimum Cl_2 Residual at 1st User (C) [3]	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? [3]	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.38	80	110.4	22.1	7.11	18.4	YES	87.7
2	1.37	80	109.6	22.9	7.07	17.1	YES	101.9
3	1.34	80	107.2	21.2	7.13	19.6	YES	101.7
4	1.16	80	92.8	19.9	7.05	20.3	YES	94.2
5	1.32	80	105.6	22.2	7.00	17.4	YES	97.6
6	1.25	80	100.0	21.5	7.03	18.3	YES	90.9
7	1.35	80	108.0	21.5	7.00	18.3	YES	94.3
8	1.33	80	106.4	21.1	7.00	18.8	YES	90.8
9	1.31	80	104.8	22.3	7.08	17.8	YES	104
10	1.22	80	97.6	23.5	7.11	16.4	YES	105.4
11	1.37	80	109.6	24.0	7.01	15.5	YES	93.9
12	1.33	80	106.4	23.7	6.98	15.6	YES	109.9
13	1.44	80	115.2	22.5	7.02	17.4	YES	103.4
14	1.41	80	112.8	22.7	6.78	15.6	YES	102.6
15	1.21	80	96.8	21.9	6.94	17.1	YES	97.8
16	1.32	80	105.6	21.4	6.91	17.7	YES	97.1
17	1.29	80	103.2	20.9	6.90	18.2	YES	97.7
18	1.36	80	108.8	20.4	7.05	20.1	YES	97.1
19	1.4	80	112.0	22.0	7.10	18.5	YES	94.4
20	1.45	80	116.0	21.0	6.51	15.9	YES	86.6
21	1.38	80	110.4	22.3	6.58	14.8	YES	92.7
22	1.37	80	109.6	21.5	6.92	17.8	YES	88.8
23	1.33	80	106.4	23.5	6.91	15.4	YES	91
24	1.4	80	112.0	23.7	6.82	14.8	YES	91.9
25	1.38	80	110.4	22.6	6.85	16.1	YES	83.2*
26	1.31	80	104.8	22.3	6.87	16.4	YES	82.8*
27	1.31	80	104.8	22.2	6.82	16.2	YES	78.3*
28	1.45	80	116.0	22.4	6.86	16.5	YES	79.3*
29	1.31	80	104.8	21.9	6.67	15.6	YES	78.8*
30	1.41	80	112.8	21.5	6.80	17.1	YES	75.1*
31	1.53	80	122.4	21.0	6.93	18.8	YES	80.0*

*Avg hourly flow calculated from total daily flow while Mill flow collection system was down

[3] If Cl_2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350