

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: Linn

Month/Year: Sep-25

System Name:	Cascade Pacific Pulp			ID#:	OR4192152		WTP : TP -	A
Day	7 AM [NTU]	11 AM [NTU]	3 PM [NTU]	7 PM [NTU]	11 PM [NTU]	3 AM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.13	0.10	0.10	0.12	0.11	0.12	0.13	
2	0.12	0.14	0.16	0.12	0.10	0.11	0.16	
3	0.18	0.13	0.13	0.22	0.12	0.14	0.22	
4	0.12	0.13	0.14	0.15	0.15	0.16	0.16	
5	0.15	0.13	0.15	0.15	0.14	0.19	0.19	
6	0.17	0.13	0.13	0.14	0.13	0.13	0.17	
7	0.17	0.14	0.15	0.14	0.13	0.14	0.17	
8	0.08	0.07	Power Outage	No Water	0.11	0.13	0.13	
9	0.08	0.07	0.08	0.10	0.10	0.10	0.10	
10	0.12	0.17	0.11	0.06	0.10	0.07	0.17	
11	0.10	0.12	0.12	0.08	0.07	0.10	0.12	
12	0.11	0.10	0.11	0.11	0.10	0.14	0.14	
13	0.11	0.11	0.12	0.11	0.11	0.13	0.13	
14	0.12	0.11	0.09	0.11	0.06	0.10	0.12	
15	0.10	0.09	0.11	0.11	0.10	0.08	0.11	
16	0.08	0.10	0.06	0.07	0.09	0.10	0.10	
17	0.07	0.08	0.07	0.08	0.10	0.09	0.10	
18	0.10	0.15	0.10	0.08	0.10	0.10	0.15	
19	0.08	0.09	0.10	0.10	0.08	0.10	0.10	
20	0.12	0.11	0.11	0.12	0.13	0.14	0.14	
21	0.12	0.12	0.14	0.14	0.14	0.16	0.16	
22	0.12	0.15	0.13	0.14	0.13	0.15	0.15	
23	0.14	0.12	0.13	0.13	0.13	0.14	0.14	
24	0.10	0.11	0.10	0.12	0.10	0.12	0.12	
25	0.12	0.06	0.06	0.07	0.09	0.10	0.12	
26	0.12	0.14	0.11	0.10	0.10	0.12	0.14	
27	0.11	0.13	0.11	0.10	0.10	0.10	0.13	
28	0.15	0.14	0.15	0.17	0.15	0.14	0.17	
29	0.14	0.13	0.15	0.11	0.15	0.12	0.15	
30	0.11	0.15	0.13	0.12	0.13	0.12	0.15	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes No		
Notes:		PRINTED NAME: Darrel Lockard SIGNATURE: Darrel Lockard PHONE #: (541) 505-9968	
		DATE: 10/3/2025 CERT #: 2853	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form
WTP - :
System Name:
ID#: 41
Month/Year:
**Disinfection *Giardia*
Log Inactive:**
1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM
1	1.24	80	99.2	21.6	6.99	17.9	YES	101.5
2	1.14	80	91.2	23.0	7.01	16.2	YES	106.2
3	1.56	80	124.8	22.7	6.81	16.1	YES	100.9
4	1.22	80	97.6	22.6	6.98	16.6	YES	101.8
5	1.19	80	95.2	22.1	7.01	17.3	YES	96.7
6	1.37	80	109.6	22.2	6.95	17.2	YES	111.8
7	1.44	80	115.2	22.2	6.95	17.3	YES	112.1
8	1.38	80	110.4	21.2	7.04	19.0	YES	87.8
9	1.19	80	95.2	20.6	7.10	19.8	YES	103.3
10	1.25	80	100.0	20.0	7.08	20.6	YES	98.1
11	1.23	80	98.4	20.5	7.16	20.5	YES	106.9
12	1.43	80	114.4	19.6	6.94	20.5	YES	106.9
13	1.34	80	107.2	21.0	7.16	20.1	YES	98.3
14	1.22	80	97.6	20.7	7.00	19.0	YES	102.6
15	0.86	80	68.8	19.3	7.15	21.2	YES	104
16	1.43	80	114.4	21.0	7.17	20.4	YES	106.5
17	1.67	80	133.6	20.4	7.06	20.9	YES	104.2
18	1.47	80	117.6	21.0	7.16	20.4	YES	105.6
19	1.43	80	114.4	20.4	7.00	19.9	YES	102.5
20	1.48	80	118.4	20.8	7.11	20.3	YES	105.9
21	1.49	80	119.2	20.0	7.06	21.1	YES	107
22	1.52	80	121.6	19.5	7.09	22.1	YES	103.5
23	1.39	80	111.2	19.1	7.12	22.6	YES	102.8
24	1.54	80	123.2	19.7	7.08	21.8	YES	99.6
25	1.54	80	123.2	20.4	7.01	20.2	YES	99.5
26	1.46	80	116.8	19.1	7.06	22.3	YES	95.1
27	1.39	80	111.2	20.1	7.04	20.5	YES	99.3
28	1.47	80	117.6	20.0	7.04	20.8	YES	97.6
29	1.51	80	120.8	19.7	6.88	20.1	YES	96.9
30	1.56	80	124.8	18.6	7.02	23.0	YES	87.9
31		80						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2