

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Linn

Conventional or Direct Filtration

Month/Year: Oct-25

System Name:	Cascade Pacific Pulp			ID#:	OR4192152		WTP : TP -	A
Day	7 AM [NTU]	11 AM [NTU]	3 PM [NTU]	7 PM [NTU]	11 PM [NTU]	3 AM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.11	0.13	0.12	0.13	0.14	0.13	0.14	
2	0.12	0.15	0.12	0.10	0.13	0.11	0.15	
3	0.12	0.12	0.12	0.13	0.14	0.13	0.14	
4	0.12	0.14	0.14	0.13	0.13	0.12	0.14	
5	0.12	0.14	0.12	0.13	0.13	0.14	0.14	
6	0.12	0.12	0.04	0.04	0.05	0.05	0.12	
7	0.04	0.06	0.04	0.06	0.04	0.07	0.07	
8	0.04	0.04	0.03	0.08	0.04	0.04	0.08	
9	0.05	0.11	0.07	0.04	0.06	0.04	0.11	
10	0.06	0.06	0.04	0.04	0.03	0.05	0.06	
11	0.05	0.04	0.06	0.06	0.03	0.04	0.06	
12	0.06	0.05	0.07	0.06	0.06	0.07	0.07	
13	0.03	0.04	0.05	0.05	0.04	0.05	0.05	
14	0.05	0.04	0.03	0.06	0.03	0.03	0.06	
15	0.04	0.05	0.05	0.04	0.06	0.04	0.06	
16	0.04	0.06	0.05	0.05	0.04	0.04	0.06	
17	0.04	0.04	0.06	0.04	0.04	0.04	0.06	
18	0.04	0.05	0.05	0.06	0.05	0.07	0.07	
19	0.04	0.06	0.04	0.05	0.04	0.05	0.06	
20	0.05	0.05	0.07	0.05	0.04	0.05	0.07	
21	0.03	0.04	0.04	0.07	0.04	0.04	0.07	
22	0.06	0.06	0.04	0.08	0.04	0.05	0.08	
23	0.04	0.05	0.04	0.05	0.06	0.04	0.06	
24	0.06	0.05	0.05	0.05	0.06	0.07	0.07	
25	0.06	0.04	0.07	0.04	0.04	0.03	0.07	
26	0.04	0.06	0.06	0.06	0.07	0.04	0.07	
27	0.06	0.10	0.08	0.04	0.06	0.05	0.10	
28	0.04	0.05	0.08	0.06	0.06	0.06	0.08	
29	0.08	0.04	0.05	0.07	0.06	0.06	0.08	
30	0.09	0.04	0.04	0.06	0.06	0.04	0.09	
31	0.06	0.06	0.04	0.04	0.05	0.07	0.07	

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: Darrel Lockard

SIGNATURE: Darrel Lockard

Digitally signed by Darrel Lockard
DN: cn=Darrel Lockard, o=Cascade Pacific Pulp, ou=, email=lockard.darrel@cppl.com, c=US

DATE: 11/4/2025

PHONE #: (541) 505-9968

CERT #: T-2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	ID#: 41	Month/Year:	WTP - :	
			Disinfection <i>Giardia</i> Log Inactive:	1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.57	80	125.6	18.3	7.02	23.5	YES	80.6
2	1.43	80	114.4	18.2	6.99	23.0	YES	96.8
3	1.35	80	108.0	17.9	6.93	22.7	YES	86.7
4	1.4	80	112.0	19.1	6.96	21.3	YES	94.9
5	1.4	80	112.0	18.8	6.95	21.7	YES	104.4
6	1.46	80	116.8	18.1	7.00	23.3	YES	91.1
7	1.44	80	115.2	18.9	7.02	22.2	YES	98
8	1.44	80	115.2	18.8	7.11	23.1	YES	85.8
9	1.45	80	116.0	17.1	7.11	26.0	YES	97
10	1.4	80	112.0	16.7	7.10	26.4	YES	85.2
11	1.43	80	114.4	17.0	7.09	25.9	YES	93.8
12	1.21	80	96.8	16.7	7.08	25.6	YES	94.6
13	1.36	80	108.8	16.2	6.98	26.0	YES	89.7
14	1.37	80	109.6	15.7	7.10	28.1	YES	97.4
15	1.38	80	110.4	15.1	7.10	29.3	YES	82.9
16	1.38	80	110.4	16.1	7.15	27.9	YES	96.7
17	1.51	80	120.8	15.8	7.10	28.4	YES	82.9
18	1.47	80	117.6	16.6	7.12	27.0	YES	91.6
19	1.44	80	115.2	16.5	6.99	25.8	YES	94.1
20	1.33	80	106.4	16.0	6.97	26.2	YES	89.5
21	1.35	80	108.0	15.7	7.13	28.4	YES	103.7
22	1.36	80	108.8	16.0	7.05	27.0	YES	84.7
23	1.34	80	107.2	16.5	7.14	27.0	YES	99.8
24	1.33	80	106.4	16.4	7.16	27.3	YES	87.5
25	1.17	80	93.6	15.2	7.03	27.7	YES	99.5
26	1.31	80	104.8	14.3	7.01	29.7	YES	98.2
27	1.26	80	100.8	14.0	7.08	30.9	YES	89.7
28	1.48	80	118.4	14.1	7.04	31.0	YES	78.5
29	1.2	80	96.0	15.0	7.09	28.8	YES	79.7
30	1.24	80	99.2	14.7	7.04	29.0	YES	78.9
31	1.3	80	104.0	14.1	7.08	30.8	YES	77.7

If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350