

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Linn

Conventional or Direct Filtration

Month/Year: Nov-25

System Name:	Cascade Pacific Pulp			ID#:	OR4192152		WTP : TP -	A
Day	7 AM [NTU]	11 AM [NTU]	3 PM [NTU]	7 PM [NTU]	11 PM [NTU]	3 AM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.07	0.06	0.07	0.05	0.06	0.06	0.07	
2	0.05	0.07	0.04	0.03	0.03	0.06	0.07	
3	0.04	0.07	0.09	0.05	0.04	0.04	0.09	
4	0.03	0.08	0.08	0.06	0.04	0.07	0.08	
5	0.04	0.08	0.06	0.04	0.08	0.06	0.08	
6	0.10	0.07	0.06	0.06	0.09	0.08	0.10	
7	0.10	0.05	0.07	0.07	0.07	0.05	0.10	
8	0.05	0.04	0.06	0.07	0.06	0.09	0.09	
9	0.04	0.04	0.04	0.05	0.06	0.05	0.06	
10	0.07	0.08	0.05	0.08	0.07	0.05	0.08	
11	0.04	0.08	0.05	0.05	0.09	0.08	0.09	
12	0.04	0.09	0.05	0.09	0.06	0.07	0.09	
13	0.10	0.05	0.06	0.04	0.07	0.06	0.10	
14	0.11	0.04	0.06	0.05	0.05	0.04	0.11	
15	0.05	0.04	0.06	0.12	0.08	0.08	0.12	
16	0.06	0.04	0.06	0.15	0.08	0.10	0.15	
17	0.05	0.04	0.05	0.05	0.05	0.06	0.06	
18	0.05	0.06	0.06	0.08	0.05	0.05	0.08	
19	0.04	0.05	0.06	0.05	0.04	0.05	0.06	
20	0.05	0.04	0.04	0.05	0.08	0.04	0.08	
21	0.09	0.10	0.06	0.04	0.07	0.03	0.10	
22	0.06	0.05	0.05	0.03	0.04	0.05	0.06	
23	0.10	0.05	0.04	0.08	0.10	0.05	0.10	
24	0.05	0.04	0.06	0.09	0.04	0.04	0.09	
25	0.03	0.05	0.04	0.04	0.06	0.04	0.06	
26	0.05	0.06	0.06	0.04	0.05	0.05	0.06	
27	0.03	0.04	0.06	0.04	0.07	0.06	0.07	
28	0.05	0.06	0.04	0.04	0.05	0.05	0.06	
29	0.04	0.05	0.06	0.06	0.04	0.04	0.06	
30	0.06	0.04	0.05	0.06	0.06	0.04	0.06	
							0.00	

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

CT's met everyday?
(see back)

Yes / No

All Cl2 residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: Darrel Lockard

SIGNATURE: Darrel Lockard

DATE: 12/3/2025

PHONE #: (541) 505-9968

CERT #: 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:

ID#: 41

Month/Year:

Disinfection *Giardia*
Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.37	80	109.6	15.5	7.07	28.2	YES	75.7
2	1.8	80	144.0	15.0	7.12	31.2	YES	77.6
3	1.33	80	106.4	14.2	7.05	30.4	YES	80.3
4	1.67	80	133.6	14.4	7.19	32.8	YES	79.6
5	1.38	80	110.4	14.8	7.13	30.3	YES	78.6
6	1.38	80	110.4	15.1	7.03	28.6	YES	79.4
7	1.19	80	95.2	14.9	7.17	29.8	YES	76.9
8	1.34	80	107.2	14.2	7.12	31.2	YES	74.9
9	1.37	80	109.6	13.8	7.12	32.2	YES	80
10	1.32	80	105.6	14.0	7.18	32.3	YES	81.4
11	1.32	80	105.6	14.4	7.16	31.2	YES	74.6
12	1.32	80	105.6	14.6	7.15	30.7	YES	78.5
13	1.45	80	116.0	14.9	7.18	30.9	YES	81.6
14	1.37	80	109.6	15.0	7.21	30.7	YES	81.5
15	1.12	80	89.6	15.1	7.22	29.8	YES	83.1
16	1.41	80	112.8	14.8	7.18	30.9	YES	81.3
17	1.4	80	112.0	13.9	7.18	32.8	YES	89.6
18	1.41	80	112.8	12.2	6.96	34.6	YES	79
19	1.37	80	109.6	11.5	6.95	35.9	YES	85.3
20	1.39	80	111.2	11.9	7.03	36.0	YES	89.5
21	1.38	80	110.4	11.9	6.96	35.1	YES	78.9
22	1.3	80	104.0	11.5	7.04	36.7	YES	77.6
23	1.33	80	106.4	11.6	7.17	38.3	YES	80.4
24	1.29	80	103.2	11.1	7.07	38.0	YES	87.8
25	1.24	80	99.2	11.1	7.11	38.3	YES	80.1
26	1.29	80	103.2	11.5	7.06	36.9	YES	81.3
27	1.46	80	116.8	12.5	7.08	34.9	YES	79.9
28	1.19	80	95.2	12.5	7.17	35.0	YES	83.8
29	1.2	80	96.0	12.2	7.11	35.5	YES	80.6
30	1	80	80.0	11.8	7.00	34.4	YES	80.1

If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2