

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Linn

Conventional or Direct Filtration

Month/Year: Jan-26

| System Name: | Cascade Pacific Pulp |             | ID#:       | OR4192152  |             |            | WTP : TP -                                    | A |
|--------------|----------------------|-------------|------------|------------|-------------|------------|---|---|
| Day          | 7 AM [NTU]           | 11 AM [NTU] | 3 PM [NTU] | 7 PM [NTU] | 11 PM [NTU] | 3 AM [NTU] | Highest Reading of the Day <sup>1</sup> [NTU] |   |
| 1            | 0.13                 | 0.07        | 0.07       | 0.09       | 0.10        | 0.09       | 0.13  |   |
| 2            | 0.10                 | 0.11        | 0.09       | 0.06       | 0.09        | 0.09       | 0.11  |   |
| 3            | 0.07                 | 0.07        | 0.08       | 0.08       | 0.07        | 0.08       | 0.08  |   |
| 4            | 0.08                 | 0.07        | 0.07       | 0.08       | 0.08        | 0.06       | 0.08  |   |
| 5            | 0.08                 | 0.06        | 0.07       | 0.06       | 0.08        | 0.07       | 0.08  |   |
| 6            | 0.08                 | 0.05        | 0.07       | 0.07       | 0.08        | 0.07       | 0.08  |   |
| 7            | 0.08                 | 0.05        | 0.05       | 0.06       | 0.07        | 0.08       | 0.08  |   |
| 8            | 0.06                 | 0.07        | 0.07       | 0.07       | 0.06        | 0.06       | 0.07  |   |
| 9            | 0.12                 | 0.09        | 0.10       | 0.08       | 0.07        | 0.06       | 0.12  |   |
| 10           | 0.08                 | 0.09        | 0.07       | 0.10       | 0.09        | 0.09       | 0.10  |   |
| 11           | 0.07                 | 0.08        | 0.06       | 0.06       | 0.07        | 0.11       | 0.11  |   |
| 12           | 0.08                 | 0.08        | 0.07       | 0.07       | 0.08        | 0.08       | 0.08  |   |
| 13           | 0.09                 | 0.08        | 0.07       | 0.08       | 0.09        | 0.09       | 0.09  |   |
| 14           | 0.11                 | 0.10        | 0.11       | 0.11       | 0.07        | 0.08       | 0.11  |   |
| 15           | 0.07                 | 0.08        | 0.05       | 0.08       | 0.05        | 0.06       | 0.08  |   |
| 16           | 0.04                 | 0.13        | 0.05       | 0.05       | 0.05        | 0.06       | 0.13  |   |
| 17           | 0.08                 | 0.07        | 0.05       | 0.04       | 0.05        | 0.03       | 0.08  |   |
| 18           | 0.03                 | 0.03        | 0.04       | 0.03       | 0.04        | 0.07       | 0.07  |   |
| 19           | 0.04                 | 0.04        | 0.03       | 0.04       | 0.04        | 0.10       | 0.10  |   |
| 20           | 0.06                 | 0.06        | 0.05       | 0.03       | 0.03        | 0.03       | 0.06  |   |
| 21           | 0.09                 | 0.10        | 0.10       | 0.06       | 0.04        | 0.04       | 0.10  |   |
| 22           | 0.04                 | 0.04        | 0.04       | 0.07       | 0.07        | 0.10       | 0.10  |   |
| 23           | 0.04                 | 0.05        | 0.04       | 0.05       | 0.07        | 0.06       | 0.07  |   |
| 24           | 0.05                 | 0.04        | 0.08       | 0.07       | 0.07        | 0.08       | 0.08  |   |
| 25           | 0.04                 | 0.06        | 0.03       | 0.07       | 0.06        | 0.09       | 0.09  |   |
| 26           | 0.08                 | 0.03        | 0.05       | 0.03       | 0.06        | 0.02       | 0.08  |   |
| 27           | 0.05                 | 0.05        | 0.05       | 0.03       | 0.09        | 0.03       | 0.09  |   |
| 28           | 0.07                 | 0.04        | 0.06       | 0.06       | 0.05        | 0.03       | 0.07  |   |
| 29           | 0.05                 | 0.07        | 0.03       | 0.03       | 0.04        | 0.03       | 0.07  |   |
| 30           | 0.05                 | 0.09        | 0.05       | 0.09       | 0.04        | 0.03       | 0.09  |   |
| 31           | 0.04                 | 0.05        | 0.08       | 0.11       | 0.03        | 0.04       | 0.11  |   |

| Conventional or Direct Filtration   | Monthly Summary (Answer Yes or No)   |  |
|---|--|--|
| 95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No        | CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No           | All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No |
| All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No             |  |  |
| All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="checkbox"/> Yes / No |  |  |
| Notes:  | PRINTED NAME: Darrel Lockard<br>SIGNATURE: Darrel Lockard<br>PHONE #: (541) 505-9968 |  |
|   | DATE: 2/5/2026<br>CERT #: 2853   |  |

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

|                     |                |                    |        |                                    |   |
|---------------------|----------------|--------------------|--------|------------------------------------|---|
| <b>System Name:</b> | <b>ID#: 41</b> | <b>Month/Year:</b> | 26-Jan | <b>WTP - :</b>                     |   |
|                     |                |                    |        | <b>Disinfection <i>Giardia</i></b> | 1 |
|                     |                |                    |        | <b>Log Inactive:</b>               |   |

| Date / Time | Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> | Contact Time (T) | Actual CT | Temp | pH   | Required CT | CT Met? <sup>3</sup> | Peak Hourly Demand Flow |
|-------------|---|------------------|-----------|------|------|-------------|----------------------|-------------------------|
|             | [ppm or mg/L]   | [minutes]        | C X T     | ° C  |      | formula     | Yes / No             | [GPM]                   |
| 1           | 1.4   | 80               | 112.0     | 9.5  | 7.17 | 44.3        | YES                  | 77.6                    |
| 2           | 1.4   | 80               | 112.0     | 11.0 | 7.35 | 42.7        | YES                  | 82.4                    |
| 3           | 1.46  | 80               | 116.8     | 10.6 | 7.38 | 44.6        | YES                  | 83.2                    |
| 4           | 1.29  | 80               | 103.2     | 11.1 | 7.48 | 43.9        | YES                  | 81.9                    |
| 5           | 1.46  | 80               | 116.8     | 11.0 | 7.64 | 47.6        | YES                  | 86.8                    |
| 6           | 1.4   | 80               | 112.0     | 10.6 | 7.24 | 42.2        | YES                  | 80.2                    |
| 7           | 1.37  | 80               | 109.6     | 10.0 | 7.15 | 42.4        | YES                  | 78.5                    |
| 8           | 1.37  | 80               | 109.6     | 9.9  | 7.30 | 45.0        | YES                  | 77.4                    |
| 9           | 1.28  | 80               | 102.4     | 9.6  | 7.75 | 53.3        | YES                  | 80.8                    |
| 10          | 1.33  | 80               | 106.4     | 9.2  | 7.45 | 49.5        | YES                  | 76.3                    |
| 11          | 1.31  | 80               | 104.8     | 10.2 | 7.42 | 45.7        | YES                  | 78.4                    |
| 12          | 1.37  | 80               | 109.6     | 9.8  | 7.40 | 46.9        | YES                  | 87.2                    |
| 13          | 1.4   | 80               | 112.0     | 9.7  | 7.10 | 42.6        | YES                  | 85.2                    |
| 14          | 1.49  | 80               | 119.2     | 9.1  | 7.13 | 45.3        | YES                  | 85.7                    |
| 15          | 1.5   | 80               | 120.0     | 9.0  | 7.11 | 45.3        | YES                  | 88.8                    |
| 16          | 1.42  | 80               | 113.6     | 8.7  | 7.16 | 46.6        | YES                  | 91.6                    |
| 17          | 1.44  | 80               | 115.2     | 9.9  | 7.09 | 42.1        | YES                  | 87.4                    |
| 18          | 1.46  | 80               | 116.8     | 8.9  | 7.11 | 45.4        | YES                  | 88.3                    |
| 19          | 1.45  | 80               | 116.0     | 7.9  | 7.15 | 49.1        | YES                  | 106.1                   |
| 20          | 1.47  | 80               | 117.6     | 7.5  | 7.18 | 51.1        | YES                  | 108.2                   |
| 21          | 1.4   | 80               | 112.0     | 7.8  | 7.05 | 47.5        | YES                  | 109.1                   |
| 22          | 1.56  | 80               | 124.8     | 6.7  | 6.85 | 48.5        | YES                  | 110                     |
| 23          | 1.45  | 80               | 116.0     | 8.7  | 7.04 | 44.8        | YES                  | 105.6                   |
| 24          | 1.49  | 80               | 119.2     | 6.9  | 7.10 | 51.9        | YES                  | 104.5                   |
| 25          | 1.48  | 80               | 118.4     | 6.5  | 7.08 | 52.8        | YES                  | 112.8                   |
| 26          | 1.39  | 80               | 111.2     | 6.8  | 7.11 | 51.8        | YES                  | 111.9                   |
| 27          | 1.38  | 80               | 110.4     | 7.6  | 7.10 | 48.9        | YES                  | 106.2                   |
| 28          | 1.55  | 80               | 124.0     | 8.7  | 7.04 | 45.3        | YES                  | 106.5                   |
| 29          | 1.5   | 80               | 120.0     | 10.2 | 7.03 | 40.7        | YES                  | 103.4                   |
| 30          | 1.44  | 80               | 115.2     | 9.6  | 7.10 | 43.1        | YES                  | 94.5                    |
| 31          | 1.39  | 80               | 111.2     | 9.5  | 7.12 | 43.4        | YES                  | 93.8                    |

If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

**Return by 10th of following month by email, fax, or mail to:**  
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350