

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: **Linn**

Conventional or Direct Filtration

Month/Year: **Feb-26**

System Name:	Cascade Pacific Pulp			ID#:	OR4192152		WTP : TP -	A
Day	7 AM [NTU]	11 AM [NTU]	3 PM [NTU]	7 PM [NTU]	11 PM [NTU]	3 AM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.05	0.07	0.06	0.06	0.04	0.06	0.07	
2	0.08	0.06	0.06	0.05	0.06	0.03	0.08	
3	0.04	0.05	0.06	0.06	0.04	0.05	0.06	
4	0.04	0.05	0.04	0.04	0.07	0.04	0.07	
5	0.03	0.03	0.04	0.03	0.05	0.05	0.05	
6	0.03	0.03	0.06	0.04	0.04	0.04	0.06	
7	0.06	0.05	0.06	0.07	0.05	0.04	0.07	
8	0.07	0.06	0.04	0.07	0.08	0.05	0.08	
9	0.09	0.03	0.05	0.05	0.04	0.04	0.09	
10	0.03	0.05	0.03	0.03	0.06	0.08	0.08	
11	0.08	0.06	0.03	0.08	0.05	0.05	0.08	
12	0.05	0.03	0.03	0.07	0.06	0.04	0.07	
13	0.07	0.08	0.07	0.04	0.04	0.07	0.08	
14	0.06	0.05	0.07	0.06	0.04	0.06	0.07	
15	0.09	0.06	0.07	0.06	0.06	0.06	0.09	
16	0.08	0.09	0.08	0.08	0.07	0.06	0.09	
17	0.06	0.04	0.06	0.05	0.09	0.05	0.09	
18	0.03	0.06	0.03	0.05	0.08	0.04	0.08	
19	0.04	0.04	0.04	0.03	0.03	0.07	0.07	
20	0.06	0.04	0.07	0.09	0.05	0.04	0.09	
21	0.07	0.04	0.08	0.06	0.04	0.05	0.08	
22	0.04	0.03	0.04	0.05	0.05	0.04	0.05	
23	0.05	0.08	0.08	0.05	0.07	0.09	0.09	
24	0.07	0.05	0.06	0.10	0.08	0.07	0.10	
25	0.06	0.10	0.07	0.08	0.06	0.07	0.10	
26	0.05	0.12	0.06	0.06	0.06	0.10	0.12	
27	0.07	0.03	0.05	0.04	0.04	0.04	0.07	
28	0.05	0.05	0.06	0.08	0.08	0.06	0.08	

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? All 4-hour turbidity readings ≤ 1 NTU? All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes:	PRINTED NAME: Darrel Lockard	
	SIGNATURE: Darrel Lockard	DATE: 3/5/2026
	PHONE #: (541) 505-9968	CERT #: 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

