

OHA - Drinking Water Services - Surface Water Quality Data Form

Cartridge or Bag Filtration

County: Hood River

Month/Year: 

System Name: Lost Lake Campground		ID#: 41	92627	WTP ID: TP- A		
Day	Δ PSI of Pre-Filters Train 1 / Train 2	Δ PSI of Main Filters Train 1 / Train 2	Total PSID = Sum of ΔPSI Train 1 / Train 2	Total PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	2 2	2 2	4 4	25.00	.42	
2	11 6	4 6	8 12		.42	
3	4 7	5 7	9 14		.43	
4	5 7	6 8	11 15		.40	
5	10 12	9 10	19 22		.43	
6	12 14	12 11	24 25		.52	
7	2 0	2 0	4 0		.48	
8	6 8	6 8	12 16		.42	
9	12 12	12 12	24 24		.48	
10	2 2	2 2	4 4		.40	
11	0 0	0 0	0 0			
12	10 12	12 10	22 22		.48	
13	2 2	2 2	4 4		.52	
14	8 6	6 8	14 14		.40	
15	0 0	0 0	0 0			
16	0 0	0 0	0 0			
17	12 12	12 12	24 24		.48	
18	0 0	0 0	0 0			
19	2 4	4 6	6 10		.46	
20	10 12	12 10	22 22		.42	
21	2 3	2 2	4 4		.42	
22	0 0	0 0	0 0			
23	0 0	0 0	0 0			
24	12 12	12 12	24 24		.52	
25	2 4	4 2	6 6		.48	
26	0 0	0 0	0 0			
27	6 8	8 6	14 14		.42	
28	12 13	12 12	24 25		.42	
29	2 0	0 2	4 4		.46	
30	6 6	6 6	12 12		.43	
31	12 12	12 12	24 24		.48	

Cartridge & Bag Filtration

95% of daily turbidity readings ≤ 1 NTU?

Yes / No

All daily turbidity readings ≤ 5 NTU?

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back)

Yes / No

All Cl₂ residual at entry point ≥ 0.2 mg/l?

Yes / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: *Dylan Reid*

SIGNATURE: *[Signature]*

DATE:

PHONE #: ()

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: USFS Lost Lake	ID#: 41	Month/Year:	WTP: 92627
Disinfection Giardia Log Inactiv:			1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.2	116	139.2	15.1	7.8	35	Y	
2	1.2	116	139.2	15.5	7.7	33	Y	
3	1.0	116	116	15.0	7.6	31	Y	
4	1.0	116	116	14.2	7.2	30	Y	
5	1.0	116	116	14.1	7.5	33	Y	
6	1.2	116	139.2	14.3	7.5	34	Y	
7	1.8	116	208.8	14.0	7.4	35	Y	
8	1.4	116	162.4	14.0	7.9	40	Y	
9	1.6	116	185.6	14.1	7.8	40	Y	
10	1.8	116	208.8	14.2	7.8	41	Y	
11	1.6	116	185.6	14.1	7.6	27	Y	
12	1.8	116	208.8	15.3	7.6	34	Y	
13	1.0	116	116	15.2	7.8	34	Y	
14	1.0	116	116	15.4	7.4	29	✓	
15	1.0	116	116	15.4	7.2	27	✓	
16	1.0	116	116	15.0	7.4	29	✓	
17	1.0	116	116	14.0	7.3	31	Y	
18	1.8	116	116	14.2	7.2	30	Y	
19	1.0	116	116	14.2	7.4	32	Y	
20	1.0	116	116	14.3	7.5	33	Y	
21	1.2	116	139.2	14.9	7.4	33	Y	
22	1.4	116	162.4	15.2	7.6	32	Y	
23	1.4	116	162.4	15.0	7.8	35	✓	
24	1.6	116	185.6	15.4	7.4	31	✓	
25	2.0	116	232	14.9	7.9	34	✓	
26	2.0	116	232	15.5	7.0	34	Y	
27	1.8	116	208.8	15.0	7.4	32	Y	
28	1.4	116	162.4	15.5	7.2	28	✓	
29	1.6	116	185.6	15.2	7.4	38	✓	
30	1.8	116	208.8	15.4	7.8	37	✓	
31	1.8	116	208.8	15.4	8.0	40	✓	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised November 2022

MT HOUND NATIONAL FOREST FILTRATION RECORDS FOR LOST LAKE RESORT AND CAMPGROUND

Month:	Turbidity	Chlorine	Temp.	PH	Daily Run 1 (backwall)	Running Total 1	Daily Run 2 (floor)	Running Total 2	Daily Pump (coffin)	Running Pump	Resort
1	.42	1.2	15.1	7.8	813771	771	16076033	2500			
2	.52	1.2	15.5	7.7	814251	480	16077533	1500			
3	.48	1.0	15.0	7.6	814911	660	16079725	2170			
4	.40	1.0	14.2	7.2	815338	427	16083375	3650			
5	.48	1.0	14.1	7.5	815732	394	16087133	3760			
6	.52	1.2	14.3	7.5	816165	433	160891053	1,920			
7	.48	1.8	14.0	7.4	816446	281	16090683	1,630			
8	.42	1.4	14.0	7.9	816796	350	16090693	10			
9	.48	1.6	14.1	7.8	817138	342	16092493	1,800			
10	.48	1.8	14.2	7.8	817631	2193	160941543	2,050			
11	.48	1.6	14.1	7.6	818145	514	160941543	0			
12	.48	1.8	15.3	7.6	818498	355	16097233	2,690			
13	.52	1.0	15.2	7.8	819079	581	16102093	4,860			
14	.48	1.0	15.1	7.4	819318	239	16103423	1730			
15	.48	1.0	15.4	7.2	819728	390	16103823	0			
16	.48	1.0	15.0	7.1	820114	406	16103823	0			
17	.48	1.0	14.0	7.3	820612	498	16108993	5170			
18	.46	1.8	14.2	7.2	820828	216	16108993	0			
19	.46	1.0	14.2	7.4	821171	343	16111193	2,200			
20	.42	1.0	14.3	7.5	821519	348	16114843	3,650			
21	.42	1.2	14.4	7.4	821814	245	16116303	1460			
22	.42	1.4	15.2	7.6	822130	366	16116303	0			
23	.42	1.4	15.0	7.8	822591	411	16116303	0			
24	.52	1.6	15.1	7.4	823273	682	16118643	2340			
25	.48	2.0	15.4	7.4	823722	449	16122333	3680			
26	.48	2.0	15.5	7.4	824059	337	16122333	0			
27	.42	1.8	15.0	7.4	824345	291	16123873	1540			
28	.42	1.1	15.5	7.2	824641	296	16125083	1190			
29	.48	1.6	15.2	7.4	824884	243	16128833	3790			
30	.48	1.8	15.4	7.8	825447	563	16134053	5220			
31	.48	1.8	15.4	8.0	826337	890	16134653	5600			

Notes:

LOST LAKE RESORT FILTRATION RECORDS - WATER PUMPED

Month:	Time	Daily Run 1 (backwall)	Running Total 1	Daily Run 2 (floor)	Running Total 2	Daily Pump (coffin)	Running Pump	Tank
	1 12:00	813771	1771	16076033	2500			
	2 12:00	814251	480	16077553	1,520			
	3 12:00	814911	660	16079723	2170			
	4 12:00	815338	427	16083373	3650			
	5 12:00	815732	394	16087133	3760			
	6 12:00	816165	433	16089053	1,920			
	7 12:00	816446	281	16090683	1630			
	8 12:00	816796	350	16090693	10			
	9 12:00	817138	342	16092493	1,800			
	10 12:00	817631	493	16094543	2,050			
	11 12:00	818145	514	16094543	0			
	12 12:00	818498	353	16097233	2,690			
	13 12:00	819079	581	16102093	4,860			
	14 12:00	819318	239	16103823	1730			
	15 12:00	819708	390	16103823	0			
	16 12:00	820114	406	16103823	0			
	17 12:00	820612	498	16108993	5170			
	18 12:00	820828	216	16108993	0			
	19 12:00	821171	343	16111193	2,200			
	20 12:00	821519	348	16114843	3,650			
	21 12:00	821814	295	16116303	1460			
	22 12:00	822180	366	16116303	0			
	23 12:00	822591	411	16116303	0			
	24 12:00	823273	682	16118643	2340			
	25 12:00	823722	449	16122333	3690			
	26 12:00	824054	332	16122333	0			
	27 12:00	824345	291	16123873	1540			
	28 12:00	824641	296	16125063	1190			
	29 12:00	824884	243	16128833	3770			
	30 12:00	825447	563	16134053	5220			
	31 12:00	826337	890	16139633	5600			

Notes: