

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Douglas

Cartridge or Bag Filtration

Month/Year: Jul-21

System Name: USFS Wolf Creek CG Umpqua NF		ID#: 41	92762	WTP ID: TP-	A	
Day	Filter 1 PSID	Filter 2 PSID	Filter 3 PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	52-44	52-54	53-54	15.00	0.20	0.20
2	45-40	43-45	45-46	15.00	0.21	0.21
3	45-40	43-45	45-46	15.00	0.21	0.21
4	44-39	40-43	43-44	15.00	0.23	0.23
5	42-38	40-42	45-45	15.00	0.21	0.21
6	50-42	50-50	50-50	15.00	0.20	0.20
7	45-40	45-46	46-47	15.00	0.19	0.19
8	45-40	43-45	46-47	15.00	0.19	0.19
9	44-39	42-45	45-46	15.00	0.20	0.20
10	43-36	40-42	44-45	15.00	0.20	0.20
11	50-46	47-48	50-50	15.00	0.21	0.21
12	50-42	49-50	50-51	15.00	0.19	0.19
13	42-38	41-42	42-44	15.00	0.19	0.19
14	46-40	48-47	47-48	15.00	0.20	0.20
15	42-42	45-46	48-49	15.00	0.19	0.19
16	42-38	50-48	48-48	15.00	0.19	0.19
17	50-48	50-47	49-49	15.00	0.18	0.18
18	44-39	43-44	45-45	15.00	0.19	0.19
19	42-38	42-44	43-44	15.00	0.18	0.18
20	48-42	46-48	49-50	15.00	0.17	0.17
21	43-38	42-42	42-44	15.00	0.17	0.17
22	48-42	50-45	45-45	15.00	0.17	0.17
23	49-42	46-46	46-47	15.00	0.15	0.15
24	44-40	43-39	35-35	15.00	0.17	0.17
25	47-42	45-39	39-40	15.00	0.17	0.17
26	47-40	45-40	40-40	15.00	0.16	0.16
27	50-42	52-42	40-40	15.00	0.16	0.16
28	50-44	50-48	40-39	15.00	0.15	0.15
29	42-44	45-29	27-28	15.00	0.17	0.17
30	58-52	55-54	55-53	15.00	0.24	0.24
31	45-40	45-45	47-46	15.00	0.21	0.21

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME:	
		SIGNATURE:	DATE:
		PHONE #: ()	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: USFS Wolf Creek CG

ID#: 41 92762

Month/Year: Jul-21

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	1.1	58	64	21	7.9	28	Yes	15
2	1.3	58	75	20	7.9	28	Yes	15
3	1.4	58	81	21	7.9	28	yes	15
4	1.6	58	92	22	7.9	29	yes	15
5	1.4	58	81	21	7.9	28	yes	15
6	1.3	58	75	21	7.9	28	Yes	15
7	1.5	58	87	21	7.9	29	Yes	15
8	1.5	58	87	21	7.9	29	Yes	15
9	1.5	58	87	20	7.9	29	Yes	15
10	1.6	58	92	20	7.9	29	yes	15
11	1.8	58	104	22	7.8	30	yes	15
12	1.4	58	81	21	7.9	28	Yes	15
13	1.4	58	81	21	7.9	28	Yes	15
14	0.6	58	86	21	7.9	28	Yes	15
15	1.3	58	75	21	7.9	28	yes	15
16	1.1	58	64	20	7.8	28	yes	15
17	1.4	58	81	20	7.9	28	yes	15
18	1.3	58	75	20	7.9	28	yes	15
19	1.4	58	81	21	7.8	28	Yes	15
20	1.3	58	75	21	7.8	28	Yes	15
21	1.3	58	75	21	7.8	28	Yes	15
22	1.3	58	75	19	7.9	38	yes	15
23	1.4	58	81	19	7.8	38	Yes	15
24	1.7	58	98	19	7.9	40	yes	15
25	1.6	58	92	20	7.8	29	yes	15
26	1.4	58	81	21	7.8	28	Yes	15
27	1.4	58	81	22	7.8	28	Yes	15
28	1.2	58	69	22	7.8	28	yes	15
29	1.3	58	75	22	7.8	28	yes	15
30	1.4	58	81	23	7.8	28	Yes	15
31	1.5	58	140	23	7.8	29	Yes	15

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

Wolf Creek Campground Flow Sheet for July 2021 Month/Year

Date	Time	Meter Reading	Gallons	Initial	Comments (include filter changes)
1		4859770	460	DG	
2		4860230	1,070	DG	Change baseplate filter (12 PSI/P)
3		4861300	1320	GL	
4		4862620	250	GL	
5		4863370	770	GL	
6		4864140	710	DG	
7		4864850	700	DG	
8		4865550	810	DG	
9		4866360	740	DG	
10		4867100	1080	GL	
11		4868180	400	GL	
12		4868580	340	DG	
13		4868920	450	DG	
14		486 9370	420	DG	
15		4869790	620	GL	
16		487 0410	710	GL	
17		4871120	890	GL	
18		4872010	340	GL	
19		4872350	280	DG	
20		487 2630	200	DG	
21		4872830	350	DG	
22		4873180	360	GL	
23		4873540	830	DG	
24		4874320	840	GL	
25		4875210	470	GL	
26		4875680	460	DG	
27		4876140	230	DG	
28		487 676320	590	GL	
29		4876960	740	GL	Change 500 filter
30		4877700	650	JS	
31		4878350	900	JS	