

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Douglas

Cartridge or Bag Filtration

Month/Year: Sep-22

Day	Filter 1 PSID	Filter 2 PSID	Filter 3 PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	41-37	41-43	42-43	15.00	0.158	0.158
2	52-44	52-49	50-50	15.00	0.162	0.162
3	41-37	40-42	41-42	15.00	0.163	0.163
4	46-40	44-46	46-47	15.00	0.191	0.191
5	41-37	41-42	42-43	15.00	0.166	0.166
6	48-41	46-47	46-46	15.00	0.141	0.141
7	47-40	45-46	47-49	15.00	0.181	0.181
8	45-39	42-32	32-30	15.00	0.19	0.19
9	Pol	Pol	Pol	15.00	Pol	Pol
10	Pol	Pol	Pol	15.00	Pol	Pol
11	41-37	40-42	41-42	15.00	0.167	0.167
12	44-39	42-44	44-45	15.00	0.169	0.169
13	40-36	40-41	42-43	15.00	0.160	0.160
14	44-39	42-45	44-46	15.00	0.175	0.175
15	40-37	40-41	41-42	15.00	0.165	0.165
16	41-38	40-42	42-43	15.00	0.151	0.151
17	43-39	42-44	44-45	15.00	0.161	0.161
18	43-40	42-44	44-46	15.00	0.145	0.145
19	42-39	41-42	42-43	15.00	0.270	0.270
20	42-38	41-41	42-43	15.00	0.196	0.196
21	45-40	44-46	46-48	15.00	0.195	0.195
22	45-40	44-45	45-47	15.00	0.190	0.190
23	48-42	47-46	46-47	15.00	0.174	0.174
24	47-41	46-45	45-47	15.00	0.152	0.152
25	42-38	41-43	43-44	15.00	0.146	0.146
26	46-41	44-45	45-46	15.00	0.159	0.159
27	48-42	47-45	44-43	15.00	0.153	0.153
28	Pol			15.00		
29	Pol			15.00		
30	Pol			15.00		
31				15.00		

**END OF SEASON**

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)
95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes: PSI = pounds per square inch  
 PSID = pounds per square inch difference (before filter - after filter)  
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Jonathan Woody  
 SIGNATURE: *John Woody* DATE: 10-7-22  
 PHONE #: (541) 643-6137 CERT #: 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: USFS Wolf Creek CG	ID#: 41	92762	Month/Year: Sep-22	Disinfection Giardia Log Inactiv: 1
---------------------------------	---------	-------	--------------------	-------------------------------------

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	0.9	58	52	20	7.3	22	Yes	15
2	0.9	58	52	19	7.4	30	Yes	15
3	1.1	58	64	19	7.5	31	Yes	15
4	1.2	58	70	18	7.5	31	Yes	15
5	1.1	58	64	19	7.5	31	Yes	15
6	0.7	58	41	19	7.5	29	Yes	15
7	0.7	58	41	19	7.5	29	Yes	15
8	0.6	58	35	18	7.6	35	Yes	15
9	Pol	58	Pol	Pol	Pol	Pol	Pol	15
10	Pol	58	Pol	Pol	Pol	Pol	Pol	15
11	0.7	58	41	19	7.5	29	Yes	15
12	0.7	58	41	18	7.5	29	Yes	15
13	1.0	58	58	18	7.5	30	Yes	15
14	0.8	58	46	17	7.6	35	Yes	15
15	0.7	58	41	17	7.5	29	Yes	15
16	0.9	58	52	16	7.5	30	Yes	15
17	0.9	58	52	15	7.5	30	Yes	15
18	1.1	58	64	15	7.6	37	Yes	15
19	0.8	58	46	15	7.5	29	Yes	15
20	0.8	58	46	16	7.5	29	Yes	15
21	1.0	58	58	17	7.5	30	Yes	15
22	0.5	58	29	16	7.5	29	Yes	15
23	0.6	58	35	15	7.5	29	Yes	15
24	0.6	58	35	15	7.5	29	Yes	15
25	0.8	58	46	15	7.5	29	Yes	15
26	0.8	58	46	16	7.5	29	Yes	15
27	1.1	58	64	17	7.5	31	Yes	15
28	<del>Pol</del>	58						15
29	Pol	58						15
30	Pol	58						15
31		58						15

END OF SEASON

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours