

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Douglas

Cartridge or Bag Filtration

Month/Year: Sep-23

System Name:	USFS Wolf Creek CG Umpqua NF			ID#:	41 92762	WTP ID:	TP-	A
Day	Filter 1 PSID	Filter 2 PSID	Filter 3 PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU]		
1	43-40	46-45	45-43	15.00	0.20	0.20		
2	49-41	51-51	48-48	15.00	0.22	0.22		
3	57-49	52-53	53-52	15.00	0.19	0.19		
4	55-50	55-55	57-54	15.00	0.16	0.16		
5	45-39	43-43	41-44	15.00	0.18	0.18		
6	55-50	55-54	55-54	15.00	0.16	0.16		
7	55-49	54-54	54-54	15.00	0.17	0.17		
8	51-43	54-54	50-50	15.00	0.16	0.16		
9	39-33	40-40	40-40	15.00	0.18	0.18		
10	40-34	40-40	42-42	15.00	0.17	0.17		
11	39-34	40-40	40-40	15.00	0.17	0.17		
12	48-41	47-46	46-46	15.00	0.18	0.18		
13	42-37	42-41	41-41	15.00	0.16	0.16		
14	45-39	43-43	43-42	15.00	0.19	0.19		
15				15.00				
16				15.00				
17				15.00				
18				15.00				
19				15.00				
20				15.00				
21				15.00				
22				15.00				
23				15.00				
24				15.00				
25				15.00				
26				15.00				
27				15.00				
28				15.00				
29				15.00				
30				15.00				
31				15.00				

Closed for Season

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No		
Notes: PSI = pounds per square inch	PRINTED NAME: Jonathan Woodly	
PSID = pounds per square inch difference (before filter - after filter)	SIGNATURE: <i>John Woodly</i>	DATE: 10/9/23
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.	PHONE #: (541) 643-6137	CERT #: 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: USFS Wolf Creek CG

ID#: 41 92762

Month/Year: Sep-23

Disinfection  
Giardia Log  
Inactiv:

1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	0.8	58	46	16	7.3	29	Yes	15
2	1.0	58	58	16	7.3	30	Yes	15
3	0.9	58	52	18	7.2	30	Yes	15
4	1.0	58	58	17	7.3	30	Yes	15
5	0.9	58	52	16	7.3	30	Yes	15
6	0.9	58	52	15	7.3	30	Yes	15
7	1.0	58	58	15	7.3	30	Yes	15
8	0.9	58	52	15	7.3	30	Yes	15
9	0.6	58	35	16	7.3	29	Yes	15
10	1.0	58	58	17	7.2	30	Yes	15
11	1.1	58	64	16	7.3	31	Yes	15
12	1.0	58	58	17	7.3	30	Yes	15
13	1.1	58	64	17	7.2	31	Yes	15
14	1.1	58	64	17	7.2	31	Yes	15
15		58						15
16		58						15
17		58						15
18		58						15
19		58						15
20		58						15
21		58						15
22		58						15
23		58						15
24		58						15
25		58						15
26		58						15
27		58						15
28		58						15
29		58						15
30		58						15
31		58						15

Closed For Season

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.