

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Linn

Cartridge or Bag Filtration

Month/Year: Jul-25

System Name: Whispering Falls ID#: 41 92786 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	10.00	0.00	10.00	25.00	0.19	
2	10.00	0.00	10.00	25.00	0.20	
3	10.00	0.00	10.00	25.00	0.18	
4	10.00	0.00	10.00	25.00	0.16	
5	10.00	0.00	10.00	25.00	0.18	
6	12.00	0.00	12.00	25.00	0.17	
7	12.00	0.00	12.00	25.00	0.16	
8	12.00	0.00	12.00	25.00	0.14	
9	12.00	0.00	12.00	25.00	0.18	
10	15.00	0.00	15.00	25.00	0.14	
11	15.00	0.00	15.00	25.00	0.15	
12	15.00	0.00	15.00	25.00	0.17	
13	15.00	0.00	15.00	25.00	0.16	
14	18.00	0.00	18.00	25.00	0.17	
15	18.00	0.00	18.00	25.00	0.19	
16	19.00	0.00	19.00	25.00	0.15	
17	5.00	0.00	5.00	25.00	0.14	
18	5.00	0.00	5.00	25.00	0.16	
19	5.00	0.00	5.00	25.00	0.15	
20	5.00	0.00	5.00	25.00	0.17	
21	5.00	0.00	5.00	25.00	0.18	
22	7.00	0.00	7.00	25.00	0.18	
23	7.00	0.00	7.00	25.00	0.17	
24	7.00	0.00	7.00	25.00	0.16	
25	7.00	0.00	7.00	25.00	0.18	
26	7.00	0.00	7.00	25.00	0.17	
27	7.00	0.00	7.00	25.00	0.17	
28	7.00	0.00	7.00	25.00	0.19	
29	8.00	0.00	8.00	25.00	0.18	
30	8.00	0.00	8.00	25.00	0.17	
31	8.00	0.00	8.00	25.00	0.19	

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	(Yes)	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	(Yes)	(Yes / No)	(Yes)
Notes: PSI = pounds per square inch		PRINTED NAME: Adam Brenner	
PSID = pounds per square inch difference (before filter - after filter)		SIGNATURE: <i>Adam Brenner</i>	DATE: 8-6-25
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.		PHONE #: 541 381-4767	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP :

System Name:	Whispering Falls	ID#: 41	92786	Month/Year:	Jul-25	Disinfection <i>Giardia</i> Log Inactiv:	1
--------------	------------------	---------	-------	-------------	--------	--	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 / 2pm	0.8	82	65.6	12.7	8.00	44.9	YES	
2 / 2pm	0.7	82	57.4	12.6	8.10	46.4	YES	
3 / 2pm	0.8	82	65.6	12.8	8.20	48.0	YES	
4 / 2pm	0.7	82	57.4	12.7	8.00	44.4	YES	
5 / 2pm	0.7	82	57.4	12.5	8.00	45.0	YES	
6 / 2pm	0.9	82	73.8	12.8	8.00	45.1	YES	
7 / 2:30pm	0.9	82	73.8	13.4	8.00	43.4	YES	
8 / 2pm	0.9	82	73.8	13.5	8.00	43.1	YES	
9 / 2pm	0.8	82	65.6	13.4	8.10	44.5	YES	
10 / 2pm	0.8	82	65.6	13.7	8.10	43.6	YES	
11 / 2pm	0.9	82	73.8	13.9	8.10	43.5	YES	
12 / 2:30pm	1	82	82.0	14.0	8.10	43.7	YES	
13 / 2:30pm	1	82	82.0	14.5	8.20	43.9	YES	
14 / 2pm	1	82	82.0	14.3	8.20	44.5	YES	
15 / 2pm	1	82	82.0	14.7	8.10	41.7	YES	
16 / 2pm	0.9	82	73.8	14.5	8.10	41.8	YES	
17 / 2pm	1.1	82	90.2	14.5	8.10	42.8	YES	
18 / 2pm	1.2	82	98.4	14.6	8.30	46.3	YES	
19 / 2pm	0.8	82	65.6	14.8	8.30	43.6	YES	
20 / 2pm	1	82	82.0	14.5	8.30	45.5	YES	
21 / 2pm	1	82	82.0	14.6	8.30	45.2	YES	
22 / 2pm	0.9	82	73.8	14.5	8.40	46.7	YES	
23 / 2pm	0.9	82	73.8	14.4	8.40	47.0	YES	
24 / 2pm	1	82	82.0	14.5	8.40	47.2	YES	
25 / 2pm	1	82	82.0	14.7	8.40	46.6	YES	
26 / 2pm	0.9	82	73.8	14.5	8.40	46.7	YES	
27 / 2pm	1	82	82.0	14.6	8.50	48.7	YES	
28 / 2pm	0.9	82	73.8	14.8	8.30	44.1	YES	
29 / 2:30pm	0.9	82	73.8	15.5	8.30	42.1	YES	
30 / 2pm	0.8	82	65.6	15.4	8.40	43.5	YES	
31 / 2pm	0.9	82	73.8	15.4	8.50	45.6	YES	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dlw.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350