

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Linn

Cartridge or Bag Filtration

Month/Year: Sep-22

System Name: Riverside ID#: 41 92787 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	8.00	0.00	8.00	25.00	0.38	
2	10.00	0.00	10.00	25.00	0.35	
3	11.00	0.00	11.00	25.00	0.32	
4	14.00	0.00	14.00	25.00	0.20	
5	15.00	0.00	15.00	25.00	0.23	
6	16.00	0.00	16.00	25.00	0.24	
7	16.00	0.00	16.00	25.00	0.26	
8	18.00	0.00	18.00	25.00	0.20	
9	18.00	0.00	18.00	25.00	0.21	
10	18.00	0.00	18.00	25.00	0.22	
11	18.00	0.00	18.00	25.00	0.26	
12	18.00	0.00	18.00	25.00	0.22	
13	18.00	0.00	18.00	25.00	0.26	
14	18.00	0.00	18.00	25.00	0.21	
15	19.00	0.00	19.00	25.00	0.18	
16	19.00	0.00	19.00	25.00	0.21	
17	15.00	0.00	15.00	25.00	0.21	
18	8.00	0.00	8.00	25.00	0.31	
19	8.00	0.00	8.00	25.00	0.18	
20	8.00	0.00	8.00	25.00	0.25	
21	8.00	0.00	8.00	25.00	0.25	
22	10.00	0.00	10.00	25.00	0.16	
23	10.00	0.00	10.00	25.00	0.21	
24	10.00	0.00	10.00	25.00	0.23	
25	10.00	0.00	10.00	25.00	0.25	
26	10.00	0.00	10.00	25.00	0.24	
27	10.00	0.00	10.00	25.00	0.22	
28	10.00	0.00	10.00	25.00	0.11	
29	10.00	0.00	10.00	25.00	0.22	
30	10.00	0.00	10.00	25.00	0.35	
31	10.00	0.00	10.00	25.00	0.13	

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	yes	CT's met everyday? (see back)
All daily turbidity readings ≤ 5 NTU?	yes	All Cl2 residual at entry point ≥ 0.2 mg/l?
		yes

Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.	PRINTED NAME: Bob Ovendale	
	SIGNATURE:	DATE: 9/2/22
	PHONE #: (971)283-1557	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name:	Riverside	ID#: 41	Month/Year:	1-Sep	Disinfection <i>Giardia</i> Log Inactiv:	1
--------------	-----------	---------	-------------	-------	--	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.41	115	47.2	16.7	7.90	31.7	YES	
2	0.41	115	47.2	16.3	7.90	32.6	YES	
3	0.41	115	47.2	15.9	7.80	32.3	YES	
4	0.41	115	47.2	15.8	7.80	32.5	YES	
5	0.44	115	50.6	15.3	7.90	35.0	YES	
6	0.38	115	43.7	15.3	7.90	34.7	YES	
7	0.4	115	46.0	15.2	7.80	33.8	YES	
8	0.4	115	46.0	15.1	7.80	34.0	YES	
9	0.38	115	43.7	15.2	7.90	35.0	YES	
10	0.38	115	43.7	15.4	7.90	34.5	YES	
11	0.36	115	41.4	15.5	8.00	35.5	YES	
12	0.33	115	38.0	14.9	7.80	34.2	YES	
13	0.37	115	42.6	15.2	7.80	33.7	YES	
14	0.31	115	35.7	14.7	7.80	34.6	YES	
15	0.31	115	35.7	14.3	7.60	33.0	YES	
16	0.31	115	35.7	15.0	7.80	33.9	YES	
17	0.31	115	35.7	15.2	7.80	33.4	YES	
18	0.33	115	38.0	15.4	8.00	35.6	YES	
19	0.33	115	38.0	15.6	7.80	32.6	YES	
20	0.35	115	40.3	15.8	7.70	31.1	YES	
21	0.31	115	35.7	15.3	7.50	29.7	YES	
22	0.32	115	36.8	16.1	7.80	31.5	YES	
23	0.33	115	38.0	15.6	7.50	29.2	YES	
24	0.32	115	36.8	16.1	7.60	29.3	YES	
25	0.31	115	35.7	16.3	7.80	31.1	YES	
26	0.31	115	35.7	15.8	7.60	29.8	YES	
27	0.31	115	35.7	15.4	7.60	30.6	YES	
28	0.32	115	36.8	15.3	7.60	30.9	YES	
29	0.34	115	39.1	15.2	7.70	32.3	YES	
30	0.39	115	44.9	15.2	7.70	32.5	YES	
31	0.34	115	39.1	14.8	7.70	33.2	YES	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350