

OHA - Drinking Water Program - Surface Water Quality Data Form

County: Linn

Cartridge or Bag Filtration

Month/Year: Jun-22

System Name: USFS Big Lake ID#: 41 92802

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1			0.00	25.00		
2			0.00	25.00		
3			0.00	25.00		
4			0.00	25.00		
5			0.00	25.00		
6			0.00	25.00		
7			0.00	25.00		
8			0.00	25.00		
9			0.00	25.00		
10			0.00	25.00		
11			0.00	25.00		
12			0.00	25.00		
13	5.00	10.00	-5.00	25.00	0.39	0.39
14	15.00	20.00	-5.00	25.00	0.44	0.44
15	20.00	30.00	-10.00	25.00	0.49	0.49
16	30.00	30.00	0.00	25.00	0.57	0.57
17	30.00	40.00	-10.00	25.00	0.88	0.88
18	5.00	10.00	-5.00	25.00	0.41	0.41
19	25.00	20.00	5.00	25.00	0.78	0.78
20	5.00	20.00	-15.00	25.00	0.56	0.56
21	10.00	20.00	-10.00	25.00	0.41	0.41
22	10.00	25.00	-15.00	25.00	0.47	0.47
23	10.00	25.00	-15.00	25.00	0.31	0.31
24	15.00	30.00	-15.00	25.00	0.40	0.40
25	20.00	30.00	-10.00	25.00	0.44	0.44
26	30.00	30.00	0.00	25.00	0.61	0.61
27	30.00	40.00	-10.00	25.00	0.69	0.69
28	5.00	10.00	-5.00	25.00	0.86	0.86
29	15.00	15.00	0.00	25.00	0.43	0.43
30	20.00	10.00	10.00	25.00	0.22	0.22
31			0.00	25.00		

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	YES	YES	YES

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: William Dean
 SIGNATURE: William Dean
 801-602-8847 CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP- :

System Name:	USFS Big Lake	ID#: 41 - 92802	Month/Year:	Jun-21	Disinfection Giardia Log Inactiv:
---------------------	----------------------	------------------------	--------------------	---------------	--------------------------------------------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) <small>2</small> Minimum Cl ₂ Residual at 1st	Contact Time (T)Contact Time (T)Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <small>2CT Met? 2CT Met? 2</small>
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	yes / No
1		51	0.0			8.4	Yes
2		51	0.0			8.4	Yes
3		51	0.0			8.4	Yes
4		51	0.0			8.4	Yes
5		51	0.0			8.4	Yes
6		51	0.0			8.4	Yes
7		51	0.0			8.4	Yes
8		51	0.0			8.4	Yes
9		51	0.0			8.4	Yes
10		51	0.0			8.4	Yes
11		51	0.0			8.4	Yes
12		51	0.0			8.4	Yes
13	1.9	51	96.9	12.0	6.50	31.6	Yes
14	1.2	51	61.2	12.0	6.00	24.9	Yes
15	1.6	51	81.6	12.0	6.50	30.6	Yes
16	1.8	51	91.8	12.0	6.00	26.5	Yes
17	2.1	51	107.1	12	6	27.3	Yes
18	2.2	51	112.2	12	6	27.6	Yes
19	1	51	51.0	12	6.5	28.7	Yes
20	1.2	51	61.2	14	6	20.5	Yes
21	1.5	51	76.5	15	6.5	23.9	Yes
22	1.3	51	51.0	12	6.5	28.7	Yes
23	1.4	51	40.8	13	7	30.4	Yes
24	1	51	51.0	13	7	31.1	Yes
25	0.8	51	40.8	13	7	30.4	Yes
26	1.4	51	71.4	16	7	26.7	Yes
27	1.7	51	86.7	16	7	27.6	Yes
28	1.9	51	96.9	16	7	28.2	Yes
29	1.4	51	71.4	17	7	24.9	Yes
30	1.2	51	61.2	17	7	24.4	Yes
31		51	0.0			8.4	Yes

² If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

revised February 201