

[illegible]

System Name: Breitenbush Hot Springs		ID#: 41 93461	Month/Year: 05/22		Disinfection Giardia Log Inactiv:		1	
Date / Time	Minimum Cl2 Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.42	170	71.4	8.9	7.77	50.98997089	YES	Unknown
2	0.39	170	66.3	8.9	7.76	50.63414771	YES	Unknown
3	0.38	170	64.6	8.9	7.78	50.93810513	YES	Unknown
4	0.4	170	68	8.9	7.71	49.79737768	YES	Unknown
5	0.38	170	64.6	10.1	7.73	46.12914565	YES	Unknown
6	0.38	170	64.6	9.6	7.69	47.18943117	YES	Unknown
7	0.37	170	62.9	9.8	7.61	44.98663493	YES	Unknown
8	0.36	170	61.2	9.9	7.69	46.05222995	YES	Unknown
9	0.34	170	57.8	9.6	7.74	47.8145835	YES	Unknown
10	0.31	170	52.7	9.8	7.75	47.11938227	YES	Unknown
11	0.32	170	54.4	9.8	7.82	48.35819767	YES	Unknown
12	0.3	170	51	9.3	7.82	49.88407328	YES	Unknown
13	0.48	170	81.6	9.7	7.69	47.37835399	YES	Unknown
14	0.44	170	74.8	9.1	7.8	51.08372432	YES	Unknown
15	0.45	170	76.5	9.3	7.81	50.56743699	YES	Unknown
16	0.44	170	74.8	9.4	7.58	46.20764843	YES	Unknown
17	0.43	170	73.1	9.7	7.81	49.15825193	YES	Unknown
18	0.48	170	81.6	10.0	7.79	48.01136265	YES	Unknown
19	0.53	170	90.1	10.0	7.77	47.94444079	YES	Unknown
20	0.55	170	93.5	9.4	7.62	47.2810628	YES	Unknown
21	0.54	170	91.8	10.2	7.8	47.97737863	YES	Unknown
22	0.53	170	90.1	10.9	7.62	42.87679961	YES	Unknown
23	0.52	170	88.4	10.7	7.87	47.46558534	YES	Unknown
24	0.47	170	79.9	10.2	7.66	45.29818779	YES	Unknown
25	0.45	170	76.5	10.4	7.68	44.85134855	YES	Unknown
26	0.43	170	73.1	10.4	7.68	44.74994228	YES	Unknown
27	0.46	170	78.2	12.0	7.57	38.87582125	YES	Unknown
28	0.45	170	76.5	10.9	7.43	39.62312975	YES	Unknown
29	0.43	170	73.1	11.2	7.68	42.51385173	YES	Unknown
30	0.42	170	71.4	11.0	7.75	44.00214972	YES	Unknown
31	0.44	170	74.8	11.0	7.66	42.73020847	YES	Unknown
2 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.					Revised July 2018			
Return by 10th of following month by email, fax, or mail to: dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350								
PAGE 2 of 2								