

[illegible]

System Name: Breitenbush Hot Springs		ID#: 41 93461	Month/Year: 06/22		Disinfection Giardia Log Inactiv:		1	
Date / Time	Minimum Cl2 Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.44	170	74.8	11.1	7.72	43.47971069	YES	Unknown
2	0.44	170	74.8	11.3	7.69	42.40029904	YES	Unknown
3	0.41	170	69.7	11.7	7.6	39.92189327	YES	Unknown
4	0.38	170	64.6	11.7	7.71	41.34253842	YES	Unknown
5	0.35	170	59.5	11.6	7.72	41.64995765	YES	Unknown
6	0.37	170	62.9	11.9	7.74	41.1278737	YES	Unknown
7	0.37	170	62.9	12.4	7.77	40.22317932	YES	Unknown
8	0.36	170	61.2	12.2	7.72	40.06240644	YES	Unknown
9	0.38	170	64.6	12.6	7.36	34.14192678	YES	Unknown
10	0.38	170	64.6	12.9	7.25	32.06083083	YES	Unknown
11	0.39	170	66.3	12.7	7.28	32.93981838	YES	Unknown
12	0.36	170	61.2	13.2	7.57	35.34615879	YES	Unknown
13	0.42	170	71.4	13.1	7.51	35.0659868	YES	Unknown
14	0.68	170	115.6	14.7	7.34	30.46473088	YES	Unknown
15	0.66	170	112.2	13.0	7.42	34.98574039	YES	Unknown
16	0.39	170	66.3	14.9	7.4	29.6931811	YES	Unknown
17	0.42	170	71.4	12.2	7.71	40.19196583	YES	Unknown
18	0.46	170	78.2	12.1	7.71	40.66646453	YES	Unknown
19	0.53	170	90.1	11.6	7.41	38.15446879	YES	Unknown
20	0.54	170	91.8	14.1	7.62	34.63903717	YES	Unknown
21	0.5	170	85	11.3	7.7	42.83745114	YES	Unknown
22	0.48	170	81.6	11.7	7.61	40.37579883	YES	Unknown
23	0.49	170	83.3	12.0	7.7	40.80938136	YES	Unknown
24	0.43	170	73.1	12.4	7.78	40.63539227	YES	Unknown
25	0.45	170	76.5	12.6	7.77	40.03478992	YES	Unknown
26	0.46	170	78.2	13.1	7.76	38.62973641	YES	Unknown
27	0.44	170	74.8	13.4	7.76	37.6986683	YES	Unknown
28	0.49	170	83.3	13.5	7.8	38.19357052	YES	Unknown
29	0.49	170	83.3	14.5	7.61	33.31534616	YES	Unknown
30	0.5	170	85	14.4	7.67	34.35453358	YES	Unknown
2 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.					Revised July 2018			
Return by 10th of following month by email, fax, or mail to: dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350								
PAGE 2 of 2								