



## OHA - Drinking Water Services - Surface Water Quality Data Form

OHA - Drinking Water Services - Surface Water Quality Data Form							WTP ID:	WTP-A
System Name:	Breitenbush Hot Springs		ID#: 41 93461	Month/Year: 07/23			Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl2 Residual at 1st User ( C ) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.36	170	61.2	15.3	7.74	32.70461192	YES	Unknown
1	0.37	170	62.9	15.0	7.78	33.85024006	YES	Unknown
1	0.38	170	64.6	15.6	7.75	32.29729602	YES	Unknown
1	0.43	170	73.1	15.6	7.79	32.96589562	YES	Unknown
1	0.45	170	76.5	16.1	7.86	32.79707047	YES	Unknown
1	0.43	170	73.1	16.1	7.79	31.88562629	YES	Unknown
1	0.43	170	73.1	16.7	7.9	31.8852266	YES	Unknown
1	0.47	170	79.9	16.0	7.84	32.75041775	YES	Unknown
1	0.53	170	90.1	16.4	7.93	33.21930637	YES	Unknown
1	0.53	170	90.1	16.7	7.89	32.13108001	YES	Unknown
1	0.58	170	98.6	16.7	7.91	32.55451493	YES	Unknown
1	0.60	170	102	16.5	7.91	32.99296969	YES	Unknown
1	0.61	170	103.7	16.5	7.88	32.66593631	YES	Unknown
1	0.61	170	103.7	17.0	7.82	30.90077471	YES	Unknown
1	0.61	170	103.7	17.1	7.83	30.90073946	YES	Unknown
1	0.61	170	103.7	16.4	7.84	32.42513959	YES	Unknown
1	0.58	170	98.6	16.6	7.93	33.03995952	YES	Unknown
1	0.55	170	93.5	16.8	7.9	32.08524196	YES	Unknown
1	0.59	170	100.3	16.9	7.84	31.29080554	YES	Unknown
1	0.58	170	98.6	17.3	7.75	29.45498985	YES	Unknown
1	0.59	170	100.3	16.9	7.77	30.48962651	YES	Unknown
1	0.57	170	96.9	16.8	7.78	30.76040375	YES	Unknown
1	0.57	170	96.9	17.3	7.81	30.08349904	YES	Unknown
1	0.56	170	95.2	17.4	7.81	29.82710536	YES	Unknown
1	0.58	170	98.6	18.1	7.75	27.96265277	YES	Unknown
1	0.58	170	98.6	17.3	7.7	28.91349617	YES	Unknown
1	0.54	170	91.8	17.5	7.73	28.67500158	YES	Unknown
1	0.53	170	90.1	17.5	7.76	28.96305393	YES	Unknown
1	0.52	170	88.4	17.1	7.78	30.02374876	YES	Unknown
1	0.52	170	88.4	17.0	7.8	30.35959541	YES	Unknown
1	0.48	170	81.6	17.3	7.9	30.78662323	YES	Unknown

2 If Cl2 at entry point &lt; 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350