


OHA - Drinking Water Services - Surface Water Quality Data Form						County:	Marion
Cartridge or Bag Filtration						Month/Year:	Dec 2025
System Name: Breitenbush Hot Springs			ID#: 41-93461	WTP ID: T WTP-A			
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]	
1	70.30	64.00	6.30	15.00	0.074	0.074	
2	68.20	62.80	5.40	15.00	0.048	0.048	
3	70.10	63.60	6.50	15.00	0.052	0.052	
4	68.20	62.40	5.80	15.00	0.048	0.048	
5	69.20	62.50	6.70	15.00	0.109	0.109	
6	66.60	61.40	5.20	15.00	0.259	0.259	
7	65.70	60.80	4.90	15.00	0.129	0.129	
8	62.30	59.40	2.90	15.00	0.198	0.198	
9				15.00			
10				15.00			
11	66.70	61.20	5.50	15.00	0.361	0.361	
12	73.50	65.40	8.10	15.00	0.202	0.202	
13	74.00	65.60	8.40	15.00	0.143	0.143	
14	74.80	65.90	8.90	15.00	0.104	0.104	
15	80.10	69.00	11.10	15.00	0.123	0.123	
16	77.00	67.60	9.40	15.00	0.156	0.156	
17	73.70	65.00	8.70	15.00	1.030	1.030	
18	72.10	62.50	9.60	15.00	0.241	0.241	
19				15.00			
20				15.00			
21	63.20	58.50	4.70	15.00	0.915	0.915	
22	77.50	67.00	10.50	15.00	0.402	0.402	
23	72.50	64.80	7.70	15.00	0.245	0.245	
24	81.30	69.70	11.60	15.00	0.252	0.252	
25				15.00	0.233	0.233	
26	77.50	68.00	9.50	15.00	0.212	0.212	
27	79.10	69.20	9.90	15.00	0.217	0.217	
28	78.80	69.00	9.80	15.00	0.200	0.200	
29	78.70	69.40	9.30	15.00	0.203	0.203	
30	78.80	69.20	9.60	15.00	0.483	0.483	
31	79.30	70.10	9.20	15.00	0.188	0.188	

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	Yes	Yes	Yes

Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.	PRINTED NAME: Meghan Smith	
	SIGNATURE: 	DATE: 01-10-2026
	PHONE #: (503) 854 3320	

CERT #: D-600314 T-600314	
----------------------------------	--

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

PAGE 1 of 2

OHA - Drinking Water Services - Surface Water Quality Data Form						WTP- :
System Name: Breitenbush Hot Springs	ID#: 41-93461	Month/Year: Dec 2025	Disinfection Giardia Log Inactiv:		2	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.66	170	112.2	8.4	7.57	50.3	YES	20.3
2	0.60	170	102.0	13.1	7.56	36.5	YES	24.7
3	0.55	170	93.5	8.7	7.59	49.3	YES	19.9
4	0.51	170	86.7	8.7	7.50	47.5	YES	19
5	0.49	170	83.3	8.1	7.50	49.4	YES	20.7
6	0.49	170	83.3	9.1	7.40	44.6	YES	20.9
7	0.48	170	81.6	8.8	7.54	47.7	YES	18.7
8	0.47	170	79.9	8.7	7.58	48.7	YES	19
9	0.45	170	76.5	9.0	7.70	49.5	YES	22.1
10	0.44	170	74.8	9.4	7.58	46.2	YES	21.7
11	0.41	170	69.7	10.4	7.54	42.5	YES	21.9
12	0.39	170	66.3	9.2	7.46	44.7	YES	20.5
13	0.51	170	86.7	10.5	7.50	42.1	YES	23
14	0.63	170	107.1	9.1	7.41	45.5	YES	22.9
15	0.75	170	127.5	8.9	7.35	45.6	YES	26.4
16	0.75	170	127.5	9.6	7.52	46.3	YES	25.1
17	0.72	170	122.4	9.6	7.47	45.4	YES	27.9
18	0.72	170	122.4	9.2	7.49	46.9	YES	24.7
19	0.63	170	107.1	8.9	7.58	48.8	YES	26.1
20	0.57	170	96.9	9.9	7.58	45.2	YES	20.1
21	0.91	170	154.7	10.7	7.43	42.5	YES	14.3
22	0.70	170	119.0	9.4	7.71	49.8	YES	10.3
23	0.54	170	91.8	10.5	7.69	45.0	YES	10.9
24	0.50	170	85.0	10.5	7.57	43.1	YES	17.8
25	0.50	170	85.0	11.2	7.65	42.4	YES	9.4
26	0.53	170	90.1	8.4	7.53	49.0	YES	11.7
27	0.55	170	93.5	8.4	7.51	48.8	YES	13.1
28	0.58	170	98.6	7.9	7.46	49.7	YES	15.1
29	0.62	170	105.4	7.7	7.50	51.4	YES	16.4
30	0.66	170	112.2	7.8	7.50	51.3	YES	16.6
31	0.69	170	117.3	7.6	7.65	55.1	YES	18.2

2 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350