


**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Josephine**  
 Month/Year: **Aug-25**

System Name: **Black Bar Lodge** ID#: **41 4193465** WTP: **TP -**

| Day | 12 AM<br>[NTU] | 4 AM<br>[NTU] | 8 AM<br>[NTU] | NOON<br>[NTU] | 4 PM<br>[NTU] | 8 PM<br>[NTU] | Highest Reading of the day <sup>1</sup> [NTU] |
|-----|----------------|---------------|---------------|---------------|---------------|---------------|-----------------------------------------------|
| 1   |                |               | 0.20          |               |               |               | 0.20                                          |
| 2   |                |               | 0.20          |               |               |               | 0.20                                          |
| 3   |                |               | 0.30          |               |               |               | 0.30                                          |
| 4   |                |               | 0.20          |               |               |               | 0.20                                          |
| 5   |                |               | 0.20          |               |               |               | 0.20                                          |
| 6   |                |               | 3.00          |               |               |               | 0.30                                          |
| 7   |                |               | 0.20          |               |               |               | 0.20                                          |
| 8   |                |               | 0.20          |               |               |               | 0.20                                          |
| 9   |                |               | 0.20          |               |               |               | 0.20                                          |
| 10  |                |               | 0.20          |               |               |               | 0.20                                          |
| 11  |                |               | 0.30          |               |               |               | 0.30                                          |
| 12  |                |               | 0.30          |               |               |               | 0.30                                          |
| 13  |                |               | 0.20          |               |               |               | 0.20                                          |
| 14  |                |               | 0.20          |               |               |               | 0.20                                          |
| 15  |                |               | 0.20          |               |               |               | 0.20                                          |
| 16  |                |               | 0.20          |               |               |               | 0.20                                          |
| 17  |                |               | 0.30          |               |               |               | 0.30                                          |
| 18  |                |               | 0.20          |               |               |               | 0.20                                          |
| 19  |                |               | 0.20          |               |               |               | 0.20                                          |
| 20  |                |               | 0.20          |               |               |               | 0.20                                          |
| 21  |                |               | 0.30          |               |               |               | 0.30                                          |
| 22  |                |               | 0.30          |               |               |               | 0.30                                          |
| 23  |                |               | 0.30          |               |               |               | 0.30                                          |
| 24  |                |               | 0.20          |               |               |               | 0.20                                          |
| 25  |                |               | 0.20          |               |               |               | 0.20                                          |
| 26  |                |               | 0.20          |               |               |               | 0.20                                          |
| 27  |                |               | 0.20          |               |               |               | 0.20                                          |
| 28  |                |               | 0.20          |               |               |               | 0.20                                          |
| 29  |                |               | 0.20          |               |               |               | 0.20                                          |
| 30  |                |               | 0.20          |               |               |               | 0.20                                          |
| 31  |                |               | 0.20          |               |               |               | 0.20                                          |

|                                                            |               |                                                                                                 |                                                  |
|------------------------------------------------------------|---------------|-------------------------------------------------------------------------------------------------|--------------------------------------------------|
| <b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>         |               | <b>Monthly Summary (Answer Yes or No)</b>                                                       |                                                  |
| 95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup> | <b>Yes</b> No | CT's met everyday? (see back)                                                                   | All Cl2 residual at entry point $\geq$ 0.2 mg/l? |
| All daily turbidity readings $\leq$ 5 NTU?                 | <b>Yes</b> No | <b>Yes</b> No                                                                                   | <b>Yes</b> No                                    |
| Notes:                                                     |               | Printed Name: John M James                                                                      |                                                  |
|                                                            |               | SIGNATURE:  |                                                  |
|                                                            |               | 9/9/2025                                                                                        |                                                  |
|                                                            |               | Phone: # 541-479-6307                                                                           | CERT #:                                          |

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

## OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: Black Bar Lodge ID#: 41 93465 Month/Year: 2025 August

Disinfection *Giardia* Log

Inactiv:

1.0

| Date / Time | Minimum<br>Cl <sub>2</sub><br>Residual at<br>1st User<br>(C) <sup>3</sup> | Contact<br>Time<br>(T) | Actual CT | Temp  | pH   | Required CT | CT Met? <sup>3</sup> | Peak Hourly Demand<br>Flow |
|-------------|---------------------------------------------------------------------------|------------------------|-----------|-------|------|-------------|----------------------|----------------------------|
|             | [ppm or mg/L]                                                             | [minutes]              | C X T     | [° C] |      | formula     | Yes / No             | [GPM]                      |
| 1           | 1                                                                         | 60                     | 60.0      | 19.9  | 7.95 | 27.9        | YES                  | 20                         |
| 2           | 1                                                                         | 60                     | 60.0      | 19.7  | 7.98 | 28.6        | YES                  | 20                         |
| 3           | 1.1                                                                       | 60                     | 66.0      | 19.5  | 7.95 | 29.0        | YES                  | 20                         |
| 4           | 1.1                                                                       | 60                     | 66.0      | 19.5  | 7.95 | 29.0        | YES                  | 20                         |
| 5           | 1.1                                                                       | 60                     | 66.0      | 19.2  | 7.98 | 29.9        | YES                  | 20                         |
| 6           | 1.1                                                                       | 60                     | 66.0      | 19.4  | 7.98 | 29.5        | YES                  | 20                         |
| 7           | 1                                                                         | 60                     | 60.0      | 19.4  | 7.98 | 29.2        | YES                  | 20                         |
| 8           | 1.1                                                                       | 60                     | 66.0      | 19.4  | 7.98 | 29.5        | YES                  | 20                         |
| 9           | 1.1                                                                       | 60                     | 66.0      | 19.8  | 8.00 | 29.0        | YES                  | 20                         |
| 10          | 1.1                                                                       | 60                     | 66.0      | 19.5  | 7.98 | 29.3        | YES                  | 20                         |
| 11          | 1                                                                         | 60                     | 60.0      | 19.0  | 7.99 | 30.1        | YES                  | 20                         |
| 12          | 1                                                                         | 60                     | 60.0      | 19.1  | 8.00 | 30.0        | YES                  | 20                         |
| 13          | 1                                                                         | 60                     | 60.0      | 18.9  | 8.00 | 30.4        | YES                  | 20                         |
| 14          | 1                                                                         | 60                     | 60.0      | 18.4  | 7.95 | 30.9        | YES                  | 20                         |
| 15          | 1.1                                                                       | 60                     | 66.0      | 18.4  | 8.00 | 31.8        | YES                  | 20                         |
| 16          | 1                                                                         | 60                     | 60.0      | 18.5  | 7.98 | 31.0        | YES                  | 20                         |
| 17          | 1.1                                                                       | 60                     | 66.0      | 18.0  | 7.95 | 32.1        | YES                  | 20                         |
| 18          | 1                                                                         | 60                     | 60.0      | 18.1  | 8.00 | 32.1        | YES                  | 20                         |
| 19          | 1.1                                                                       | 60                     | 66.0      | 17.9  | 8.00 | 32.9        | YES                  | 20                         |
| 20          | 1                                                                         | 60                     | 60.0      | 18.0  | 7.98 | 32.1        | YES                  | 20                         |
| 21          | 1                                                                         | 60                     | 60.0      | 18.1  | 8.00 | 32.1        | YES                  | 20                         |
| 22          | 1.1                                                                       | 60                     | 66.0      | 17.9  | 8.00 | 32.9        | YES                  | 20                         |
| 23          | 1                                                                         | 60                     | 60.0      | 17.9  | 8.00 | 32.5        | YES                  | 20                         |
| 24          | 1                                                                         | 60                     | 60.0      | 17.5  | 7.98 | 33.2        | YES                  | 20                         |
| 25          | 1                                                                         | 60                     | 60.0      | 18.0  | 7.98 | 32.1        | YES                  | 20                         |
| 26          | 1                                                                         | 60                     | 60.0      | 18.1  | 7.98 | 31.9        | YES                  | 20                         |
| 27          | 1.1                                                                       | 60                     | 66.0      | 17.8  | 7.99 | 33.0        | YES                  | 20                         |
| 28          | 1.1                                                                       | 60                     | 66.0      | 17.8  | 7.98 | 32.9        | YES                  | 20                         |
| 29          | 1.1                                                                       | 60                     | 66.0      | 17.5  | 8.00 | 33.8        | YES                  | 20                         |
| 30          | 1                                                                         | 60                     | 60.0      | 17.3  | 8.00 | 33.8        | YES                  | 20                         |
| 31          | 1                                                                         |                        | 0.0       | 17.2  | 7.98 | 33.8        | YES                  | 20                         |

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2