

OHA - Drinking Water Services -Turbidity Monitoring Report Form							County:	jospehine
Conventional or Direct Filtration							Month/Year:	10/22
System Name:	morrison's lodge			ID#: 4193508	WTP : TP -			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]	
1			0.80					
2			0.80					
3			0.81					
4			0.79					
5			0.80					
6			0.78					
7			0.79					
8			0.78					
9			0.79					
10			0.80					
11			0.79					
12			0.80					
13			0.80					
14			0.80					
15			0.79					
16			0.79					
17			0.78					
18			0.78					
19			0.78					
20			0.78					
21			0.79					
22			0.79					
23			0.80					
24			0.79					
25			0.80					
26			0.79					
27			0.80					
28			0.80					
29			0.78					
30			0.78					
31			0.79					
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of 4-hour turbidity readings ≤ 0.3 NTU?			Yes / No	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?		
All 4-hour turbidity readings ≤ 1 NTU?			Yes / No	Yes		Yes		
All turbidity readings < IFE2 triggers			Yes / No					
Notes:				Trenton Douglas				
				Trenton Douglas		11/9/2022		
				5414799554		CERT #:		

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	
System Name:	morrison's lodge			ID#: 41	Month/Year:	21-Jul	Disinfection <i>Giardia</i> Log Inactive:	1
Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.6	76	45.6	16.6	8.00	33.9	YES	0.7104166667

2	0.8	76	60.8	16.6	8.50	41.7	YES	0.5847222222
3	1.2	76	91.2	17.7	8.40	39.1	YES	1.775
4	1.2	76	91.2	17.7	8.60	42.1	YES	0.3
5	1.2	76	91.2	18.8	8.00	31.3	YES	1.3
6	1.4	76	106.4	19.4	8.00	30.8	YES	2
7	1.4	76	106.4	17.2	8.20	38.4	YES	1.3
8	1.4	76	106.4	18.3	8.00	33.1	YES	0.8
9	1.4	76	106.4	18.3	8.40	38.4	YES	1.71.6
10	1.2	76	91.2	17.2	7.90	33.6	YES	0.7
11	1.2	76	91.2	17.2	8.40	40.4	YES	1.5
12	1.2	76	91.2	174.7	8.40	-0.8	YES	0.1
13	1.4	76	106.4	19.4	8.50	37.0	YES	2
14	1.4	76	106.4	18.8	8.40	37.2	YES	1.2
15	1.4	76	106.4	18.8	8.00	32.1	YES	0.03
16	1.4	76	106.4	17.2	8.00	35.7	YES	0.9
17	1.4	76	106.4	17.2	8.00	35.7	YES	1.1
18	1.4	76	106.4	16.1	8.00	38.4	YES	0.7
19	1.4	76	106.4	17.2	8.00	35.7	YES	0.7
20	1.4	76	106.4	17.2	8.00	35.7	YES	1
21	1.4	76	106.4	15.5	8.10	41.4	YES	1
22	1.4	76	106.4	16.6	8.20	39.9	YES	1.5
23	1.6	76	121.6	18.3	8.40	39.3	YES	1.2
24	1.4	76	106.4	17.7	8.40	40.0	YES	0.6
25	1.4	76	106.4	15.0	8.10	42.8	YES	0.8
26	1.4	76	106.4	15.5	8.00	39.9	YES	1.4
27	1.4	76	106.4	14.4	8.20	46.2	YES	0.5
28	1.6	76	121.6	15.5	8.10	42.4	YES	1
29	1.2	76	91.2	15.5	8.10	40.5	YES	1.2
30	1.2	76	91.2	16.1	8.50	45.1	YES	0.5
31	1.4	76	106.4	16.6	7.70	33.2	YES	1.3

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350