

OHA - Drinking Water Services -Turbidity Monitoring Report Form							County:	Jospehine
Conventional or Direct Filtration							Month/Year:	Jun-23
System Name:	Morrisons Rogue River Lodge			ID#: 4193508	WTP : TP -			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]	
1			0.80					
2			0.80					
3			0.81					
4			0.79					
5			0.80					
6			0.78					
7			0.79					
8			0.78					
9			0.79					
10			0.80					
11			0.79					
12			0.80					
13			0.80					
14			0.80					
15			0.79					
16			0.79					
17			0.78					
18			0.78					
19			0.78					
20			0.78					
21			0.79					
22			0.79					
23			0.80					
24			0.79					
25			0.80					
26			0.79					
27			0.80					
28			0.80					
29			0.78					
30			0.78					
31			0.79					
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of 4-hour turbidity readings ≤ 0.3 NTU?				YES	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All 4-hour turbidity readings ≤ 1 NTU?				YES	Yes		YES	
All turbidity readings < IFE2 triggers				YES				
Notes:				Trenton Douglas				
				Trenton Douglas		7/10/2023		
				5414763825		4193508		

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	1
System Name:	Morrisons Rogue River Lodge	ID#: 4193508	Month/Year:	June/2023	Disinfection Giardia Log Inactive:			
Date / Time	Minimum Cl2 Residual at 1st User ( C ) 3 [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT [ C X T ]	Temp [° C]	pH	Required CT formula	CT Met? 3 Yes / No	Peak Hourly Demand Flow [GPM]
1	1.6	76	121.6	18.3	8.10	35.2	Yes	0.81
2	1.4	76	106.4	17.2	8.20	38.4	yes	0.7
3	1.4	76	106.4	17.2	8.10	37.0	yes	1.3

4	1.5	76	114.0	17.2	8.10	37.4	yes	1.26
5	1.6	76	121.6	18.8	8.00	32.8	yes	0.93
6	1.5	76	114.0	17.2	8.00	36.1	yes	1.12
7	1.6	76	121.6	18.3	8.10	35.2	yes	2
8	1.5	76	114.0	18.3	8.00	33.5	yes	2.3
9	1.4	76	106.4	17.7	7.90	33.2	yes	2.27
10	1.2	76	91.2	18.8	8.00	31.3	yes	1.6
11	1.3	76	98.8	18.8	7.90	30.5	yes	1.88
12	1.4	76	106.4	17.7	8.00	34.5	yes	0.68
13	1.8	76	136.8	17.7	8.20	38.9	yes	1.18
14	1.7	76	129.2	17.8	8.10	36.8	yes	1.63
15	1.8	76	136.8	17.2	8.10	38.7	yes	0.87
16	1.2	76	91.2	18.3	8.10	33.6	yes	0.92
17	1	76	76.0	18.8	8.00	30.6	yes	1.96
18	1.2	76	91.2	19.4	8.00	30.1	yes	2.55
19	1.7	76	129.2	17.2	8.10	38.3	yes	1.69
20	1.6	76	121.6	16.6	8.10	39.4	yes	0.6
21	1.8	76	136.8	15.5	8.10	43.3	yes	2.33
22	1.8	76	136.8	18.3	8.00	34.7	yes	2.62
23	1.6	76	121.6	16.6	8.20	40.9	yes	1.6
24	1.4	76	106.4	18.3	8.10	34.4	yes	1.41
25	1	76	76.0	16.6	8.10	36.8	yes	1.85
26	1.4	76	106.4	17.2	8.10	37.0	yes	2.21
27	1.6	76	121.6	17.2	8.20	39.3	yes	3.26
28	1.4	76	106.4	18.3	8.10	34.4	yes	1.17
29	1.8	76	136.8	17.7	8.20	38.9	yes	1.11
30	1.2	76	91.2	19.4	8.00	30.1	yes	1.18
31								

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:  
dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350