

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Jospehine**
 Month/Year: **Jul-23**

| System Name: Morrisons Rogue River Lodge | | ID#: 4193508 | | WTP : TP - | | | |
|---|-------------|---------------------|------------|-------------------|------------|------------|------------------------------------|
| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the Day 1 [NTU] |
| 1 | | | 0.80 | | | | |
| 2 | | | 0.80 | | | | |
| 3 | | | 0.81 | | | | |
| 4 | | | 0.79 | | | | |
| 5 | | | 0.80 | | | | |
| 6 | | | 0.78 | | | | |
| 7 | | | 0.79 | | | | |
| 8 | | | 0.78 | | | | |
| 9 | | | 0.79 | | | | |
| 10 | | | 0.80 | | | | |
| 11 | | | 0.79 | | | | |
| 12 | | | 0.80 | | | | |
| 13 | | | 0.80 | | | | |
| 14 | | | 0.80 | | | | |
| 15 | | | 0.79 | | | | |
| 16 | | | 0.79 | | | | |
| 17 | | | 0.78 | | | | |
| 18 | | | 0.78 | | | | |
| 19 | | | 0.78 | | | | |
| 20 | | | 0.78 | | | | |
| 21 | | | 0.79 | | | | |
| 22 | | | 0.79 | | | | |
| 23 | | | 0.80 | | | | |
| 24 | | | 0.79 | | | | |
| 25 | | | 0.80 | | | | |
| 26 | | | 0.79 | | | | |
| 27 | | | 0.80 | | | | |
| 28 | | | 0.80 | | | | |
| 29 | | | 0.78 | | | | |
| 30 | | | 0.78 | | | | |
| 31 | | | 0.79 | | | | |

| Conventional or Direct Filtration | | Monthly Summary (Answer Yes or No) | |
|---|------------------------|------------------------------------|--|
| 95% of 4-hour turbidity readings ≤ 0.3 NTU? | YES | CT's met everyday? (see back) | All Cl2 residual at entry point ≥ 0.2 mg/l? |
| All 4-hour turbidity readings ≤ 1 NTU? | YES | Yes | YES |
| All turbidity readings < IFE2 triggers | YES | | |
| Notes: | Trenton Douglas | | |
| | Trenton Douglas | | 8/10/2023 |
| | 5414763825 | 4193508 | |

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

| System Name: Morrisons Rogue River Lodge | | ID#: 4193508 | | Month/Year: June/2023 | | WTP - : Disinfection Giardia Log Inactive: | | 1 |
|---|--|---------------------|--|------------------------------|--|---|--|----------|
|---|--|---------------------|--|------------------------------|--|---|--|----------|

| Date / Time | Minimum Cl2 Residual at 1st User (C) 3 [ppm or mg/L] | Contact Time (T) [minutes] | Actual CT C X T | Temp [° C] | pH | Required CT formula | CT Met? 3 Yes / No | Peak Hourly Demand Flow [GPM] |
|-------------|--|----------------------------|------------------------|------------|----|---------------------|--------------------|-------------------------------|
|-------------|--|----------------------------|------------------------|------------|----|---------------------|--------------------|-------------------------------|

| | | | | | | | | |
|----|-----|----|-------|------|------|------|-----|------|
| 1 | 1.4 | 76 | 106.4 | 20.0 | 8.10 | 35.2 | Yes | 1.76 |
| 2 | 1.8 | 76 | 136.8 | 19.4 | 8.10 | 33.4 | yes | 3.1 |
| 3 | 1.8 | 76 | 136.8 | 19.4 | 8.10 | 33.4 | yes | 1.47 |
| 4 | 1.8 | 76 | 136.8 | 18.8 | 8.10 | 34.8 | yes | 0.36 |
| 5 | 1.3 | 76 | 98.8 | 20.0 | 8.10 | 30.4 | yes | 3.1 |
| 6 | 1.8 | 76 | 136.8 | 20.0 | 8.10 | 32.1 | yes | 1.19 |
| 7 | 1.2 | 76 | 91.2 | 19.4 | 8.10 | 31.2 | yes | 1.78 |
| 8 | 1.2 | 76 | 91.2 | 20.0 | 8.00 | 28.9 | yes | 1.39 |
| 9 | 1.6 | 76 | 121.6 | 20.0 | 8.10 | 31.4 | yes | 1.78 |
| 10 | 1.4 | 76 | 106.4 | 19.4 | 8.40 | 35.7 | yes | 1.94 |
| 11 | 1.8 | 76 | 136.6 | 19.4 | 8.30 | 36.0 | yes | 1.12 |
| 12 | 1.8 | 76 | 136.8 | 19.4 | 8.30 | 36.0 | yes | 1.22 |
| 13 | 1.7 | 76 | 129.2 | 19.4 | 8.30 | 35.6 | yes | 1.74 |
| 14 | 1.6 | 76 | 121.6 | 20.5 | 8.30 | 32.7 | yes | 0.62 |
| 15 | 2 | 76 | 152.0 | 20.5 | 8.00 | 30.6 | yes | 1.67 |
| 16 | 1.6 | 76 | 121.6 | 21.1 | 8.10 | 29.2 | yes | 1.66 |
| 17 | 1.6 | 76 | 121.6 | 21.1 | 8.10 | 29.2 | yes | 1.61 |
| 18 | 1.6 | 76 | 121.6 | 20.5 | 8.10 | 30.4 | yes | 2.89 |
| 19 | 1.6 | 76 | 121.6 | 20.0 | 8.20 | 32.6 | yes | 1.83 |
| 20 | 1.6 | 76 | 121.6 | 20.5 | 8.20 | 31.5 | yes | 1.61 |
| 21 | 1.6 | 76 | 121.6 | 20.5 | 8.20 | 31.5 | yes | 1.02 |
| 22 | 1.6 | 76 | 121.6 | 20.5 | 8.20 | 31.5 | yes | 1.7 |
| 23 | 1.6 | 76 | 121.6 | 21.1 | 8.20 | 30.3 | yes | 1.4 |
| 24 | 1.6 | 76 | 121.6 | 21.1 | 8.30 | 31.4 | yes | 1.2 |
| 25 | 1.6 | 76 | 121.6 | 21.1 | 8.30 | 31.4 | yes | 0.93 |
| 26 | 1.6 | 76 | 121.6 | 20.5 | 8.30 | 32.7 | yes | 1.38 |
| 27 | 1.8 | 76 | 136.8 | 19.4 | 8.30 | 36.0 | yes | 2.59 |
| 28 | 1.6 | 76 | 121.6 | 19.4 | 8.20 | 33.9 | yes | 1.9 |
| 29 | 1 | 76 | 76.0 | 19.4 | 8.20 | 31.7 | yes | 1 |
| 30 | 1.8 | 76 | 136.8 | 19.4 | 8.20 | 34.7 | yes | 1.8 |
| 31 | 1.8 | 76 | 136.8 | 19.4 | 8.20 | 34.7 | yes | 1.9 |

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350